

e-45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**


No. F.6/DFS/MS/EH/2021/NDZ/ 191

Dated: 23/08/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Connaught Plaza Restaurants Pvt. Ltd. McDonalds Family Restaurant at Shop no 7, 8 & 9, Plot no. 29 & 31, Fun City Mall, East CBD Shahdara, Delhi-110032, comprised of basement, ground plus two upper floors (running at ground floor) owned/occupied by Connaught Plaza Restaurants Pvt. Ltd. was issued FSC vide letter No. F.6/DFS/MS/EH/NDZ/2018/964 dated 09/05/2018. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 10/08/2021 in the presence of Sh. Vineet Kumar Gautam, Manager and that the building is fit for occupancy Group 'D' "Assembly Building" with effect from 23/08/2021 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....23/08/2021.....at New Delhi by


(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,
The Manager,
M/s Connaught Plaza Restaurant Pvt. Ltd.,
McDonalds Family Restaurant,
Shop No. 7, 8 & 9, Plot No. 29 & 31,
Fun City Mall, East CBD Shahdara,
Delhi-110032

Copy to:-
The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone,
Karkardooma, Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per BBL.


1. Name & address of the building : M/s Connaught Plaza Restaurant Pvt. Ltd.
McDonald's Family Restaurant, Shop No. 7,8 & 9, Plot No. 29, 31, Fun City Mall, East CBD Shahdara, Delhi-110032
2. Building is comprised of : B+G+2 upper floors (running at ground floor)
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/NDZ/2018/964 dated-09/05/2018
6. Fire Safety direction letter No. : Delhi Fire Service Act, 2007 and Rules, 2010
7. Date of Inspection : 10/08/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Vineet Kumar Gautam, Manager
10. Year of Construction : 2008
11. Applicant's letter No : 2021072215632 dt-24/7/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 m	30 m	MR
	• Gate width	4.5 m	06 m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	7 nos.	MR
	• Basement	N/A	7 nos.	MR
	B. Width of Staircases			
	• Upper floor	N/A	1.5 m	MR
	• Basement	N/A	1.5 m	MR
	c. Protection of Exits			
	• Fire check door	N/A	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	2.5 m	2.5 m	MR
	f. Door Size	2 m	2 m & 1.5m	MR
	g. No of doors	2 nos.	2 nos.	MR
03	Compartmentation.	Common With mall		
	• Fire check door	N/A	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	2 hrs.	2 hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	30 a/c per hrs.	N/A	N/A
	• Upper floor	12 a/c per hrs.	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	02 nos.	03 nos.	MR
	• Types	ABC /CO ₂	ABC/ CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR


06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat or Smoke	Smoke	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	N/A	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's location	N/A	Out Side	MR
08	MOEFA	N/A	Provided	MR
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.	Common With Mall		
	• Basement	N/A	Provided	MR
	• Ground floor	N/A	Provided	MR
	• Sprinkler above false ceiling	N/A	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1 no.	1 no.	MR
	• Hose box	1 no.	1 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	3 nos.	MR
	• Hose box	N/A	3 nos.	MR
13	Pumping Arrangements.	Common With Mall		
	➤ Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	• Head of main pump	60 m	60 m	MR
	• Number of main pumps	1 no.	1 no.	MR
	• Jockey pump out put	450 LPM	450 LPM	MR
	• Jockey pump head	60 m	60 m	MR
	• Standby pump out put	2280 LPM	2280 LPM	MR
	• Standby pump head	60 m	60 m	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	Common With Mall		
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	25,000 Ltrs.	25,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	Provided in Basement		
	• Detector system panel	N/A	Provided	MR
	• Flow switch panel	N/A	Provided	MR
	• PA system panel	N/A	Provided	MR
	• Battery backup	N/A	Provided	MR
	• Building floor plans	N/A	Provided	MR
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	Provided	MR


Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.


 (Nagender Singh)
 ADO (Shahdara)


Dy. CFO (NDZ)


 13/8/21

ADO (Shah) FT is submitted please


 17/8

Dy. CFO (NDZ)


 17/8/21

mscell

