

cm

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI


No. F6/DFS/MS/School/WZ/ 632

Dated: 24/8 /2021

FIRE SAFETY CERTIFICATE

Certified that the **S.S.D. Saraswati Bal Mandir Sr. Sec. School** located at Road no. 70, West Punjabi Bagh, New Delhi comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/ School/2018/WZ/1329 dated 06/06/2018**. The premises was re-inspected by the officer concerned of this department on **02/08/2021** in the presence of **Smt. Reena Verma (Principal)** of the School and found that the said school Building have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, and that the premises is fit for occupancy class "Educational" Group B with effect from 24/8/21 for a period of three years and subject to compliance of the conditions mentioned below

Issued on 24/8/21..... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Principal, **S.S.D. Saraswati Bal Mandir Sr. Sec. School** at Road no. 70, West Punjabi Bagh, New Delhi.
2. Director of Education, Old Sectt. Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building : **S.S.D. Saraswati Bal Mandir Sr. Sec. School** located at Road No. 70, West Punjabi Bagh, New Delhi.
2. Type of Occupancy : Educational (Ground + 3 Upper Floors) & Basement
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/1329 dated 06/06/2018
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 02/08/2021
7. Name of the Inspecting Officer : Sarabjeet Singh , ADO (MN)
8. Name and designation of Officer
From the building side : Smt Reena Verma (Principal)
9. Year of Construction : 1990(As per previous Inspection report)
10. Applicant's letter No. : SBM/PB/53/2020-21/487 dated 08/04/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11/as per previous Inspection Report 29/05/2108	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 09 mtr Provided 420 cm NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2	04 Provided	MR
	<ul style="list-style-type: none"> Upper floors Basements 	01	01 Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	150cms 150cms	150X1, 2 x133, 112X1 cms 112 cm	MR MR (being old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ABC & CO ₂ ISI marked	20 nos. Provided Provided Provided	MR MR MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NR	Provided	--
	• Number of hydrants per floor	NR	Provided	--
	• Hose Box	NR	Provided	--
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NR	2 x 450 LPM Provided	NR
	➤ Head of main pump	NR	40 mtr Provided	NR
	➤ Number of main pumps	NR	01 Provided	NR
	➤ Jockey pump out put	NR	180 LPM Provided	NR
	➤ Jockey pump head	NR	40 mtr Provided	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	450 lpm Provided	MR Old case(900 lpm is provided at G.floor)
	➤ Head of the pump	Required	40 mtr Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NR	50, 000 ltrs Provided	NR
	➤ Draw off connection	NR	Provided	NR
	➤ Fire service inlet	NR	Provided	NR
	➤ Access to tank	NR	Provided	NR
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA

4-29

	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/2021/MN/339 dated 12/07/2021 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/School/2018/WZ/1329 dated 06/06/2018 renewal under DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.

~~DO (West)~~

~~Sarabjeet Singh~~
13/08/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN)

1857/ADOMN
17/08/2021

~~DO~~
16/8/2021

~~DCFO (W2)~~

~~[Signature]~~
17/8/2021

~~ADOMN~~

Sir, F.T is put up for your perusal &

Sig. No. [Signature]

~~DCFO (W2)~~

~~[Signature]~~
23/08/2021

ms/cell

~~[Signature]~~
24/8/2021