

267

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 639

Dated: 24/08/2021

FIRE SAFETY CERTIFICATE

Certified that the building Delhi International School (Great Harsh Educational welfare & Charitable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi comprised of Ground + 03 Upper Floors owned/occupied by Great Harsh Educational welfare & Charitable Society was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1739 Dated 25/07/2018. The premises was re inspected by the officers concerned of this department on 04/08/2021 in the presence of Sh. Naresh Kumar (TO) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298 -3398 Dated 01/03/2011 and that the premises is fit for occupancy class-B "Educational" with effect from 24/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/8/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Sh. Naresh Kumar Delhi International School (Great Harsh Educational welfare & Charitable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 **The fixed windows are found provided in class rooms & staircases. The windows must be converted into open able windows within one month under intimation to this department.**
- 2 The new block comprising of ground plus one upper floor shall not be used without getting FSC from this department.
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 9 Basement shall be used strictly as per building bye laws.
- 10 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Delhi International School (Great Harsh Educational welfare & Cheritable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi.
2. Type of Occupancy : Educational Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/1739 Dated 25/07/2018
5. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011.
6. Date of inspection : 04/08/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
 - a. from the building side : Sh. Naresh Kumar (TO)
9. Year of Construction : 2015
10. Applicant's letter No. : Email Dated 26-07-2021

No. of Students=739
No. of class rooms=75
Plot area=8094 M ²
Covered area=6094 M ²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/7	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	04 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	3 X 1.5mtr & 01 No 2.17 mtr	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	03 Nos.	01 No.	MR
	e. Width Of Corridor	1.5 mtr	2.1 mtr	MR
	f. Door Size	1 mtr	1.18 mtr	MR(Old Case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

M-12

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	10,000Ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/1739 Dated 25/07/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :- The fixed windows are found provided in class rooms & staircases. The windows must be converted into open able windows with in one month under intimation to this department.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *AD/DW*

12/8/21
13/08/2021
1/5/21

FF