

C-27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No: F6/DFS/MS/School/WZ/2021 / 649

Dated: 25/8 / 2021

FIRE SAFETY CERTIFICATE

Certified that the building of **S.D.M.C Primary School** located at **Vishal Enclave New Delhi – 110027** Owned/Occupied by S.D.M.C Primary School was issued FSC vide letter No. F6/DFS/MS/School/2018/WZ/1100 dated 16/05/2018. the premises was re-inspected by the officer concerned by this department on 09/08/2021 in the presence of Smt. Sarbat Parveen (Principal) of school and found that the school building deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education Govt of NCT of Delhi, and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 25/8/21..... for a period of three years and subject to compliance of the conditions mentioned below:-

Issued on .. 25/8/21..... at New Delhi.



(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Principal, S.D.M.C Primary School, Vishal Enclave New Delhi - 110027.
2. Director of Education, Old Seett, Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The auditorium shall not be used for any purpose till fire safety clearance is received from this deptt.

14001

24/8/2021

71-12

INSPECTION REPORT

1. Name & address of the building: **S. D. M. C. Primary School** located at **Vishal Enclave, New Delhi-110027.**
2. Type of Occupancy : Educational (Ground + 02 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/1100 dated 16/05/2018
5. Fire Safety directives Letter No. : Circular 3298-3398 Dated 01-03-2011.
6. Date of inspection : 09/08/2021
7. Name of the Inspecting Officer : Sarabjeet Singh , ADO (MN)
8. Name and designation of Officers
from the building side : Ms. Sarwat Parveen (Principal)
9. Year of Construction : 2014
10. Applicant's letter No. : Letter dated 28/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular 3298-3398 Dated 01-03-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1x156cm, 1X145 cms	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	2.72 m Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA


5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10nos. ABC & CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2021/342 dated 12/07/2021 have been complied.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to Renewal in accordance with the circular No.F16/Estate/CC/fire safety/2011/3298-3398 dated 01/03/2011 issued by the DO.E.is recommended.

~~160/ADO/MN~~
~~18/08/2021~~
A O (west)


18/08/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

D.O. (WEST) 175
DATED 19/08/21


19/8/2021
D O (WZ)
28/8/2021

~~ADO/MN~~ Sir, F.T letter is put up for your perusal & signature pls.


24/08/2021
D O (WZ)