

c-20

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 633

Dated: 24/08/2021

FIRE SAFETY CERTIFICATE

Certified that the building Rajkiya Pratibha Vikas Vidhalaya, Located at Sector – 19 Dwarka, New Delhi comprised of Ground + 03 Upper Floors owned/occupied by Delhi Government was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/397 Dated 12/03/2018. The premises was re inspected by the officers concerned of this department on 09/08/2021 in the presence of Sh. R.N Chauhan (HOS) and found that the said building have deemed complied with the fire prevention and fire safety requirements and that the premises is fit for occupancy class-B “Educational” with effect from 24/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24/8/21..... at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054
2. Rajkiya Pratibha Vikas Vidhalaya, at Sector – 19 Dwarka, New Delhi. (School ID-1821285)

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/7

INSPECTION REPORT

1. Name & address of the building: Rajkiya Pratibha Vikas Vidhalaya, Located at Sector – 19 Dwarka, New Delhi.
2. Type of Occupancy : Educational (Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/397 Dated 12-03-2018
5. Fire Safety directives Letter No. : UBL/NBC of India
6. Date of inspection : 09/08/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
 - a. from the building side : Sh. R.N Chauhan (HOS)
9. Year of Construction : 2017
10. Applicant's letter No. : Email Dated 30-08-2021

Total Area = 15899 sqm. Covered Area = 6360' sqm Class rooms = 24 No. of students = 450
--

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr 4.5 mtr NA	12 mtr 5.7 mtr NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements 	03 Nos. NA	04 Nos. NA	MR NA
	b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements 	3x1.5 m NA	4x1.5 mtr (including railing) NA	MR(Old case) NA
	c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	Required	02 Nos.	MR
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.20 mtr	120cm(including door frame)	MR(Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

14.	Captive water Storage for fire fighting:							
	• Under ground tank capacity	NA		50000 Ltrs.				NA
	➤ Draw off connection	NA		NA				NA
	➤ Fire service inlet	NA		NA				NA
	➤ Access to tank	NA		NA				NA
	• Overhead Tank capacity	10,000Ltr		10,000Ltr				MR
15.	Exit Signage	Required		Provided				MR
16.	Provision of Lifts							
	➤ Pressurization of Lift Shaft	NA		NA				NA
	➤ Pressurization of lift lobby	NA		NA				NA
	➤ Communication in lift Car	Required		Provided				MR
	➤ Fireman's Grounding Switch	Required		Provided				MR
	➤ Lift Signage	Required		Provided				MR
17.	Standby power supply	NA		DG set 63 KVA				NA
18.	Refuge Area							
	➤ Total area	NA		NA				NA
	➤ Location	NA		NA				NA
19.	Fire control room							
	➤ Detector system panel	NA		NA				NA
	➤ Flow Switch Panel	NA		NA				NA
	➤ PA System Panel	NA		NA				NA
	➤ Battery backup	NA		NA				NA
	➤ Building Floor Plans	NA		NA				NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required		CO2 fire extinguisher provided near electric panel				MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/397 Dated 12-03-2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Abhishek Singh*
 Designation *ADD/DW*

DO/SC

13/08/2021
By CFO (S2)

F.7.