

C-33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001


No. F6/DFS/MS/2021/School/WZ / 650

Dated: 25/8/21

FIRE SAFETY CERTIFICATE

Certified that the Building situated at **Bal Bharati Public School, Sector-14, Rohini, Delhi-110085**, comprised of **Basement + Ground + Three upper floors** owned/occupied by **Bal Bharati Public School**, has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2017/School/1732 dated 01.12.2017**. The premises was re-inspected by the officer concerned of this department on **04.02.2021** in the presence of **Smt. Geeta Gangwani (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy under Educational "Group B" with effect from 25/8/21 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..25/8/21..... at New Delhi by


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to :-

1. The Principal, Bal Bharati Public School, Sector-14, Rohini, Delhi-110085.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Bal Bharati Public School, Sector-14, Rohini, Delhi-110085.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal **(B+G+3 upper floors)**
 4. Details of Previous NOC : F.6/DFS/MS/2017/School/1732 dated 01.12.2017
 5. Fire Safety directives letter No : NBC Part-IV
 6. Date of inspection : 19.04.2021
 7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
 8. Name and designation of officers
 From the building side : Smt. Geeta Gangwani (Principal)
 9. Year of Construction : 1996
 10. Applicant's letter No. : Online mail dated 26.03.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	03	02 from ground to terrace and 01 stair + one ramp from ground to second floor only.	MR (Old Case)
	• Basements	02	03	MR
	e. Width of staircases			
	• Upper Floor	1.50m	1.50m	MR
	• Basements	1.50m	1.50m	MR
	f. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1m	1.10m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	22nos	24nos	MR
	• Types	ABC/CO2	ABC-24	MR
	• IS marking	ISI marked	YES	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	03	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	03	03	MR
	• Hose Box	03	03	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	180lpm	180lpm X 02	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm X 02	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	25000ltr	25000ltr	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000ltr	5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA

	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2017/School/1732 dated 01.12.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Note:- Request of applicant alongwith approved building plan of year 1995 show stair case provision as provided, therefore, Short coming issued at C-26 may kindly be considered completed under rule 25(c)

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

[Signature]
06/07/2021

[Signature] whether two Nos of
stair case meets out the
travel distance.

[Signature]

ADG (R)

Sir,

There are three staircase & one ramp
upto second floor. and Third floor
is having two staircase existing since
begining as per approved building plans
of DDA of 1995. and NOC/FSC's are given

[Signature]
13/08/2021

[Signature]
9/8/2021