

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / 682

Dated: 31 / 8 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **B.M. Gange Girls Senior Secondary School** located at **21, Raj Niwas Marg, Delhi-110054** comprised of **05 blocks (One Block Ground + 01 upper floor & Four Blocks Single storey only)** owned/ occupied by **B.M. Gange Girls Senior Secondary School** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/2018/NDZ/School/1951** dated **23.08.2018**. The premises was re-inspected by the officer concerned of this department on **25.08.2021** in presence of **Mrs. M.M. Philip (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from **..31.8.21.....** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on**31/8/21**... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707


Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, B.M. Gange Girls Senior Secondary School located at 21, Raj Niwas Marg, Delhi-110054

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : B.M. Gange Girls Sr. Sec. School at 21, Raj Niwas Marg, Delhi-110054.
2. Type of Occupancy : Educational (Ground + 01 upper floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/NDZ/School/1951 Dated: 23.08.2018
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 25.08.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mrs. M.M. Philip (Principal)
9. Year of Construction : Old
10. Applicant's letter No. : Online E-mail I.D Dated- 18.08.2021

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06m	20m	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02	02	MR
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.50m & 1.25m	Provided	MR
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	14nos	20nos	MR
		ABC/CO2	ABC-15/Co2-05	MR
		ISI Marked	Yes	MR

	<ul style="list-style-type: none"> Total numbers on each floor 	NA	02	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	30m	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	05mm	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	100mm	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	01	NA
	<ul style="list-style-type: none"> Hose Box 	NA	01	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	220lpm	NA
		NA	30m	NA
		N/A	Provided	N/A
		N/A	Provided	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA

	<ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1951 dated 23.08.2018.

DO (WZ)

26/08/2021

Dy CFO (WZ)

27/8/2021

[Signature]
26/08/2021
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

ADO/RN
Dy CFO (WZ)

As approved, F.T. letter is setup for your signature pl.

[Signature]
31/8/2021