

6-33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 659

Dated: 27/8/2021

FIRE SAFETY CERTIFICATE

Certified that the **Darbari Lal DAV Model School**, Located at **BN-Block, Shalimar Bagh, Pitampura, Delhi – 110034**, comprised of Two Block (BL-1=Basement + Ground + 2 Upper Floors & BL-2=Ground + 03 Upper Floors only were issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2017/WZ/1727 Dated 01.12.2017. The said premises were re inspected by the officer concerned of this department on 19.08.2021 in the presence of Sh. Sanjay Gupta (admin Officer) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy "Educational" Group B with effect from 27/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...27/8/21... at New Delhi by.


Dk (Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Darbari Lal DAV Model School, Located at BN-Block, Shalimar Bagh, Pitampura, Delhi – 110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The Basement Shall be used as per BBL.

Block, Shalimar Bagh, Pitampura, Delhi – 110034.

2. Type of Occupancy : Educational (BL-1=Basement + Ground + 2 Upper Floors & BL-2=Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2017/WZ/1727 Dated 01.12.2017
5. Fire Safety directives Letter No. : D.O.E Cir. 262-362 dated 17-01-2005
6. Date of inspection : 19.08.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Sanjay Gupta (Admin Officer)
9. Year of Construction : 2005
10. Applicant's letter No. : email dated 30.07.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cir.No.262-362 dated 17-01-2005/letter dated 01.012.2017	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 2 each floor 2 each floor 	<ul style="list-style-type: none"> BL-1=3 & BL-2=2 Provided Provided 	<ul style="list-style-type: none"> MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> BL-1=2x1.5m BL-2=1.5m 1.5m 	<ul style="list-style-type: none"> Provided BL-1=136cm & 149cm 	<ul style="list-style-type: none"> MR MR (Old Case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	01	Provided in each block	MR
	e. Width Of Corridor	1.5m	BL-1=290cm & BL-2=224cm	MR
	f. Door Size	1m	110cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> Required NA 	<ul style="list-style-type: none"> Provided Natural ventilation 	<ul style="list-style-type: none"> MR NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 36 nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose 	<ul style="list-style-type: none"> BL-1=1 & BL-2=2 30m 	<ul style="list-style-type: none"> Provided Provided 	<ul style="list-style-type: none"> MR MR

N/12

Fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings vide letter no. F6/DFS/MS/School/WZ/2021/340 dated 12.07.2021 found rectified.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E Cir. 262-362 dated 17-01-2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2017/WZ/1727 Dated 01.12.2017 is recommended.

S.P. Bhardwaj
ADO (WP)

~~DO/WZ/A~~

DO (WEST) 199
DATED. 23/08/21

~~DO~~
23/8/2021

~~DCFO (WZ)~~

~~DO~~
24/8/2021

~~ADO/WZ~~

FT is put up for signature

~~DO/WZ~~

~~DO~~
27/8/2021

~~DO~~
25/8/21

~~ADO/WZ~~