

CM5

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/SZ/2021/ 193

Dated: 24/08/2021

FIRE SAFETY CERTIFICATE

Certified that the M/S Drool kitchen (A unit of 4RS Hospitality Pvt. Ltd.), is running at ground floor of Metro Commercial Space, Metro station, Sec - 10, Dwarka, New Delhi - 110075 was issued FSC by this department vide letter no. F6/DFS/MS/EH/2012/2962 Dated 14/08/2012 (FSC has already issued to metro station sector 10 Dwarka vide letter no F6/DFS/MS/2020/SZ/179 Dated 30/03/2020) The premises was re - inspected by the officer concerned of this department on 5/08/2021 in the presence of Sh. Ravinder kumar Dhankhar and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class "Assembly" Group D with effect from 24/8/21 for a period of three years

Issued on 24/8/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Manager, M/S Drool kitchen (A unit of 4RS Hospitality Pvt. Ltd.) Metro Commercial Space, Metro station, Sec - 10, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

119
N/118

INSPECTION REPORT

1. Name & address of the building: M/S Drool kitchen (A unit of 4RS Hospitality Pvt. Ltd.) at Metro Commercial Space, Metro station, Sec - 10, Dwarka, New Delhi - 110075
2. Type of Occupancy : Class-D (Assembly)(Restaurant- Ground floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2012/2962 Dated 14/08/2012 (F6/DFS/MS/2020/SZ/179 Dated 30/03/2020 issued to Sector 10 Metro Station)
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 05/08/2021
7. Name of the Inspecting Officer ; Sh. Uday vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Ravinder kumar Dhankhar
9. Year of Construction : 2010
10. Applicant's letter No. : Email dated 20/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/7	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtrs	12 mtr	MR
		4.5 mtr	Directly accessible from road	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • Width Of Corridor • Door Size 	NA	NA	NA
		02 mtr	02 mtr 1.08 mtr	MR(Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/19

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Exhaust fans Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 Nos. ABC, CO2 ISI marked	08 Nos. ABC Provided	MR MR MR
6.	First – Aid Hose Reel			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 No 30 mtr 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Reception NA Required Near entry	Provided Reception NA Battery backup Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA Ground floor NA	NA Provided NA	NA MR NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm Ground floor Required	Provided 02 Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements: Common with Metro Station			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 40 m Required Required	1800 lpm 70 mtr 01 180 lpm 70 mtr 1800 lpm 70 mtr Provided Provided Not provided Not provided Not provided	NA NA NA NA NA NA NA NA NA MR as pump at G. level at higher sideDO.....DO.....DO.....

W/20

14.	Captive water Storage for fire fighting: Common with Metro Station			
	• Under ground tank capacity	NA	50000ltrs	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10000 ltrs	Not Provided	MR as pump at G. level at higher side
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG set 125 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/2962 Dated 14/08/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

13/8/21

Signature of the Inspecting Officer
Name: Sh. Udaivir Singh
Designation : ADO (DWK)

DO/DW
Inspection report required to be corrected for point no-13

By CFO (S2) F.F.
13/08/2021