

C-27

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2021/SZ/ 661

Dated: 27 / 8 /2021

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Boys Senior Secondary School No.-3 located at Sarojini Nagar, New Delhi-110023 comprised of Ground & Two Upper Floor only owned / Occupied by Director of Education have been issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/SZ/251 dated 15/02/2018. The premises was re-inspected by the officer concerned of this department on 13.08.2021 in the presence of Sh. N.L. Meena (HOS) and all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 27 / 8 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010

Issued on 27 / 8 /2021 at New Delhi by



(SUNIL CHAWDHARY)  
 DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The HOS, Govt. Boys Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Govt. Boys Senior Secondary School No.-3,  
Sarojini Nagar, New Delhi-110023 (Building No.-17191578).
2. Type of Occupancy : Educational
3. Type of Case : Renewal Ground & 2 Upper Floors only
4. Details of previous NOC No. F6/DFS/MS/School/2018/SZ/251 dated 15/02/2018
5. Fire Safety directives Letter No. : D.O.E. Circular Dated 01/03/2011.
6. Date of inspection : 13/08/2021
7. Name of the Inspecting Officer : A.D.O. (S.J.)
8. Name and designation of Officer  
from the building side : Sh. N.L. Meena (HOS)
9. Year of Construction : 1956
10. Applicant's letter received through Email Id-gbsss3sn@gmail.com dated 10/08/21

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. 2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	9m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m /0.75m	1.60 mtr each	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	Required	1	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	1.00m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	14	19	MR
	• Types	ABC /CO <sub>2</sub>	Provided	MR
	• IS marking	ISI Marked	Provided	MR

*(Handwritten Signature)*

	• Total numbers on each floor	2	Provided found functional	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	2	NA
	• Hose Box	NA	2	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450LPM	Provided found functional	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- 1. Shortcomings issued by this department vide letter No. F6/DFS/MS/SZ/2021/178 dated 05/04/2021 have been complied.

2. General requirements for schools as per D.O.E. Circular Dated 01/03/2011.

1. Escape route .....:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring .....:- Conduit Wiring MCB and ELCB.....  
Electric circuit .....:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set ..... :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/SZ/251 dated 15/02/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
16/08/21

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: ADO (SJ)

DO (SB)

*Duro(SJ)*

*ADP*  
17/08/21

*[Signature]*