

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No: F.6/DFS/MS/School/MN/2021/ 664

Dated: 27 / 8 / 2021

FIRE SAFETY CERTIFICATE

Certified that the building of **G.G.S.S.S, NO-1**, located at **Khyala New Delhi- 110018**. Comprised of Total Four Blocks (Two Blocks are comprised of each Ground +one upper floor & Two Blocks are comprised of each Ground floor, owned/occupied by **G.G.S.S.S, NO-1**, was issued FSC vide letter No. F6/DFS/MS/School/2018/1966 dated 28/082018 the premises was re- inspected by the officer concerned by this department on 18/08/2021 in the presence of Sh. Murli dhar (Estate Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education Govt. of NCT of Delhi and that the building / premises is fit for the occupaney class "Educational" Group B Sub Division B – 1 with effect from 27/8/21.... for a period of three years subject to compliance of the conditions mentioned below:-

Issued on 27/8/21..... at New Delhi.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to:-

1. The Principal, G.G.S.S.S, NO-1, Khyala New Delhi- 110018.
2. Directorate of Education, Old Sectt. Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: **G.G.S.S.S, NO-1, Khyala New Delhi- 110018.**
2. Type of Occupancy : Educational Four Blocks (Two BLK Ground Floor only & Two BLK Ground + 1 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/School/2018/1966 dated 28/08/2018
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 18/08/2021
7. Name of the Inspecting Officer : Sarabjeet Singh ADO (MN)
8. Name and designation of Officer from the building side : Sh. Murli Dhar (Estate Manager)
9. Year of Construction : 1976 (As per Previous Inspection report)
10. Applicant's letter No. : Email Dated 12/07/2021

Area of School -6450 sqm  
 Covered Area -1850sqm  
 Class Rooms – 38.Total  
 Students – 1657.

**The School is running in Four Blocks, Two Blocks are Ground +1 one upper floor & Two blocks are Ground floor Only.**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11/As per Prev. Ins. Report dtd.	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>2</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> </ul>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>1.5 m</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Block1 = 2X150cms&amp;Block 2=1X150 cms including railing</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> </ul>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>
	d. No of continuous staircase to terrace	1.5m	Provided	MR
	e. Width Of Corridor	1 m	2X1 m Provided	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>

*SA*



4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	7 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	5 ABC, 2 CO <sub>2</sub>	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NR	NR	MR
	• Length of hose reel hose	NR	NR	MR
	• Nozzle diameter	NR	NR	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

8/1

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/School/2018/1966 dated 28/08/2018 Renewal in accordance with the circular No.F16/Estate/CC/fire safety/2011/3298-3398 dated 01/03/2011 issued by the DO.E.is recommended.

~~179/ADO/MND D.O.(west)  
23/08/2021~~

*[Signature]*  
17/8/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

D.O. (WEST). 185  
DATED. 24/08/21

*[Signature]*  
24/8

~~DCFO (W2)~~

*[Signature]*  
25/8/2021

~~ADO/M.N.~~

Sir, F. T is put up for your personal & signature pls

~~Dy (W2)~~

*[Signature]*  
26/8/2024