

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/ 655

Dated: 27/8/21

FIRE SAFETY CERTIFICATE

Certified that Govt. Sarvodaya Kanya Vidyalaya at Khajoori Khas, Delhi- 110090, comprised of ground plus one upper floor in four separate blocks (old building only), owned/occupied by Govt. Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1439 dated 20/06/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with the circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 11/08/2021 in the presence of Ms. Kamlesh Rani, Principal of the school and that the school building is fit for occupancy class "B" 'Educational Building' with effect from 27/8/21... for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf..

Note:- This Fire Safety Certificate does not cover the new building (ground plus three upper floors) for which Fire Safety Certificate was issued earlier vide letter No. F.6/DFS/MS/School/2018/796 dated 23/04/2018 (now expired).

Issued on27/8/21..... at New Delhi by


25/8/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

o/c M2

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Khajoori Khas, Delhi-110090

Copy:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
North-East, Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

10. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya,
Khajoori Khas, Delhi-110090
11. Building is comprised of : G+3 (New building only)
12. Type of Occupancy : Educational
13. Type of Case : Renewal
14. Details of Previous NOC letter : F.6/DFS/MS/School/2018/796
dated-23/04/2018
15. Fire Safety direction letter No. : NBC Part - IV
16. Date of Inspection : 11/08/2021
17. Name of the Inspecting officers : ADO Nagender Singh
18. Name and designation of Officer
from the building side : Ms. Kamlesh Rani, Principal
10. Year of Construction : 2017
11. Applicant's email ID : skvkk_1104022@rediffmail.com
dated- 24/07/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p style="text-align: center;">6 m</p> <p style="text-align: center;">4.5 m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">6. m</p> <p style="text-align: center;">4.5 m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p>
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<p style="text-align: center;">2 nos.</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">2 nos.</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p>
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<p style="text-align: center;">1.5 m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">1.85 m & 1.93 m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p>
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
	d. No. of Continuous Staircases to Terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5 m	1.73 m	MR
	f. Door Size	1 m	1.2 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<p style="text-align: center;">8 nos.</p> <p style="text-align: center;">ABC/CO₂</p> <p style="text-align: center;">ISI marked</p>	<p style="text-align: center;">10 nos.</p> <p style="text-align: center;">ABC/ CO₂</p> <p style="text-align: center;">ISI marked</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p>

N/22

06	First-Aid-Hose Reels.			
	Total numbers on each floor	1 no.	PNF	NMR
	• Length of hose reel hose	30 m	PNF	NMR
	• Nozzle diameter	5 mm	PNF	NMR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	PNF	NMR
	• Head of the pump	40 m	PNF	NMR
	• Power supply	Required	PNF	NMR
	• Auto starting of pump	Required	PNF	NMR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

Keeping in view of the non compliance of the minimum standards of fire prevention and fire safety measures required under NBC Part-IV, it is recommended to issue shortcomings as noted at serial no. 06 & 13.

(Signature)
 (Nagender Singh)
 ADO (Shahdara)

Dy. CFO (NDZ)
(Signature)
 19/8/21



ADG (shah) FT letter is placed for signatures please

(Signature)
 20/8

(Signature)
(Signature)
 25/8/21

MS Cell