

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2021/WZ/ 678

Dated: 31/8/21

FIRE SAFETY CERTIFICATE

Certified that the **Parkash Bharti Public School St. Block, Prem Nagar-II, Durga, Mandir Road Near Kirari, Delhi-110086**, comprised of **Ground + Two upper floor owned/occupied Parkash Bharti Public School** has already been issued FSC by this department vide letter No. F.6/DFS/MS/2017/26 dated **06.01.2017**. The premises was re-inspected by the officer concerned of this department on **16.08.2021** in the presence of **Mr. Sandeep Kumar (Chairman)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premise have therefore deemed complied with the requirements of under Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy under **Group Class B (Educational)** with effect from 31/8/21 for a period of **three** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/8/21..... at New Delhi by


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to :-

1. The Principal, Parkash Bharti Public School St. Block, Prem Nagar-II, Durga, Mandir Road Near Kirari, Delhi-110086
2. The director of Education, Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Parkash Bharti Public School St. Block, Prem Nagar-2, Durga, Mandir Road Near Kirari, Delhi-
 2. Type of Occupancy : Education
 3. Type of Case : Renewal (**Ground + Two upper floor**)
 4. Details of Previous NOC : F.6/DFS/MS/2017/26 dated 06.01.2017
 5. Fire Safety directives letter No : NBC Part-IV
 6. Date of inspection : 16.08.2021
 7. Name of Inspecting Officer : ADO (Rohini)
 8. Name and designation of officers
From the building side : Mr. Sandeep Kumar (Chairman)
 9. Year of Construction : 2005, 2011 & 2015
 10. Applicant's letter No. : Online e-mail dated 24.03.2021
- PA-3052 sq.m CA-1170 sq.m No. of Students-773. No. of Class Room- 43+01 Lab

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	06 mtr	MR
		Accessible	Accessible	M.R
		NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03	03	MR
	e. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 mtr	1.89, 1.59 & 1.20m	MR(Old case)
	f. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1.05 mtr	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 No's ABC/CO2 ISI Marked	14 No's ABC/CO2 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR

Automatic fire detection and alarming system				
7.	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
			NA	NA
			NA	NA
			NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltr	10,000 ltr	MR
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	NA	NA	NA
		NA	NA	NA

N/2

	<ul style="list-style-type: none"> • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection and shortcomings issued vide this department letter no. 178 dated 11.03.2020 found rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2017/26 dated 06.01.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajaya
18/8/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajaya
18/08/2021

Dy Cfo (W2)

[Signature]
28/8/2021

ADO Rohini

FT letter to put up for kind
perusal and signature please.

DCFO (W2)

[Signature]
27/8/2021

Ajaya
26/8/21

ms/ell