

C-59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/ 654

Dated:- 26 /08/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Shadhra Angels Educational Society (Regd.) located at plot no. B-12 & B-20, Vasundhara Enclave, Delhi comprised of Basement + Ground + 04 Upper floors, owned/occupied by M/s Shadhra Angels Educational Society (Regd.), was granted FSC by this department vide letter No. F6/DFS/MS/2018/School/101 dated 17/01/2018. The premises was re-inspected by the officer concerned of this department on 19/08/2021 in the presence of the Mr. Sushant Raghav (Admn.) & Mr. Sudhir Sharma (PTI) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "B" 'Educational Building' Basement + Ground + 04 Upper floors only with effect from ...26/8/21..... for a period of three years, subject to conditions, printed below.

Issued on ...26/8/21..... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Director of Education,
GNCT of Dehi, Old Secretariat, Delhi-54.
2. The Principal,
M/s Shadhra Angels Educational Society (Regd.),
plot no. B-12 & B-20, Vasundhara Enclave, Delhi.



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building
2. Type of occupancy:-
3. Type of case:-
4. Details of previous FSC:-
5. Fire safety directives No.-
6. Date of inspection:-
7. Name of the inspecting officer:-
8. Name & designation of officer
From the building side:-
9. Year of construction:-
10. Applicant's letter No:- | M/s Shadhra Angels Educational Society (Regd.) at
plot no. B-12 & B-20, Vasundhara Enclave, Delhi
Educational Group-B
Basement + Ground + 04 Upper floors
Renewal
F6/DFS/MS/2018/School/101 dated
17/01/2018
F6/DFS/MS/BP/2013/351 dated 27.11.2013
19/08/21
Sh. Manoj Kumar Sharma (ADO/LN)
Mr. Sushant Raghav (Admn.) &
Mr. Sudhir Sharma (PTI)
(B+Gr.+02) 2005 & (3 rd & 4 th floor) 2017
email dated 10/08/2021 |
|--|--|

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	18 mtr.	MR
	2) Gate width	4.5 m	4.5 m	MR
	3) Width of internal road	6m	6 m	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 nos.	03 nos.	MR
	2. Basements	03 nos.	04 nos. + 02 ramps	MR
	B. Width of staircase			
	1. Upper floors	1.5 m	1.5 m each	MR
	2. Basements	1.5 m	1.5 m each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	03 nos.	MR
	E. Width of corridor	1.5 mtr.	2.0 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	30 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	02 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	2 nos.	2 nos.	MR
	3) Hose box	2 nos.	2 nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	2 nos.	2 nos.	MR
	2) Hose box	2 nos.	2 nos.	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	Provided	MR
	a) Discharge of main pump	N/A	900 LPM	MR
	b) Head of main pump	N/A	40 m	MR
	c) Number of main pump	N/A	01 no.	MR
	d) Jockey pump out put	N/A	450 LPM	MR
	e) Jockey pump head	N/A	40 m	MR
	f) Stand by pump output	N/A	N/A	MR
	g) Stand by pump head	N/A	N/A	MR
	h) Auto starting/Manual stopping	N/A	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	50,000 ltr.	MR
	a) Draw-off connection	N/A	Provided	MR
	b) Fire service inlet	N/A	Provided	MR
	c) Access to tank	N/A	Provided	MR
	d) Over head tank capacity	25,000 ltrs.	25,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A



17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room -	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2018/School/101 dated 17/01/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
17/8/21

Name :- M.K. Sharma
Designation :- ADO (LN)

Dy.CFO/NDZ

[Signature]
19/8/21

CFO(CR) - 9/08.

[Signature]
Director

FIRB

[Signature]

[Signature]
23/8/21

ADOC(LN)

R.T. letter is put up for sig. pl

