

C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ / 688

Dated: 02/09/21

FIRE SAFETY CERTIFICATE

Certified that the **Guru Harkrishan Public School, running at ground floor plus two upper floors** a building comprised of basement, ground floor plus two upper floors located at Tilak Nagar, New Delhi-110018, owned/occupied by Guru Harkrishan Public School was issued NOC by this department vide letter F6/DFS/MS/2017/SZ/727 dated 22/05/2017. The School building was re-inspected by the officer concerned of this department on 12/08/2021 in the presence of Sh. Kulvinder Kaur (Principal) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground plus two upper floors**) is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....02/09/21..... at New Delhi.



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER

%cyk

Copy to:-

1. The Principal,
Guru Harkrishan Public School,
Tilak Nagar, New Delhi-110018
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi -110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be used as per the building bye laws.**
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/15

INSPECTION REPORT

- 1. Name & address of the building : Guru Harkrishan Public School, Tilak Nagar, New Delhi-110018
- 2. Building is comprised of : Basement, ground plus two upper floors
- 3. Type of Occupancy : Educational
- 4. Type of Case : Renewal
- 5. Details of Previous NOC : F.6/DFS/MS/School/2017/SZ/727 dated-22/05/2017
- 6. Fire Safety direction letter No : N/A
- 7. Date of Inspection : 12/09/2021
- 8. Name of the Inspecting Officers: : ADO R.K. YADAV
- 9. Name of the designation of Officer from the building side : Sh. Kulvinder Kaur (Principal)
- 10. Year of Construction : Before 2010
- 11. Applicant's letter No : GHPS/TN/102/2021-22/GEN/4261 Dated -29/07/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	12 m	MR
	Gate width	4.5 m	05 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases Upper Floor	04 no.	04 no.	MR
	Basement	N.A.	N.A.	Basement is closed & not in use
	B. Width of Staircases Upper Floor	Old Case	1.25 m (04 no's)	MR, being old case
	Basement	N.A.	N.A.	Basement is closed & not in use
	c. Protection of exits Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	02 no.	02 no.	MR
		1.50 m	2.10 m	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Required	Exhaust Fans are provided	N.A.
	Upper floor	Required	Natural Ventilation	MR

5.	Fire Extinguisher			
	Total numbers types IS marking	08 Nos.	13 Nos.	MR
		CO ₂ & ABC	CO ₂ & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor Length of hose reel hose Nozzle diameter	04 No.	Provided	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.			
10	Automatic Sprinkler System.			
	basement upper floor sprinkler above false ceiling	Required	Provided	MR
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer Number of hydrants per floor Hose Box	N.A.	Provided	MR
		N.A.	01 no	MR
		N.A.	01 no	MR
12	Yard Hydrants.			
	Total number of hydrants Hose Box	N.A.	01 no	MR
		N.A.	01 no	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		Old case	450 lpm & 180 lpm	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
	14	Captive Water Storage for Fire Fighting.		
Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		Old Case	5,000 ltrs	MR, being old case
Required	Provided	MR		
15	Exit Signage.	Required	Provided	MR

N/17

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcoming issued vide letter no. F.6/DFS/MS/School/2021/SZ/154 Dated 23/03/2021 has been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2017/SZ/727 dated 22/05/2017 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
13/8/2021

Signature of the Inspecting Officer
Name- R.K.Yadav
Designation- A.D.O (JKP)

~~DO(SW)~~

by [Signature] 13/08/2021

ET.

A D O / J K P

FF letter is put up for sign. please

Dy CPO (SZ) [Signature]

R.K. Yadav
24/8/2021