

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 199

Dated: 27 / 8 /2021

FIRE SAFETY CERTIFICATE

Certified that M/s LIT, (A Unit of Fabulous Restaurant Pvt. Ltd) located at Ground & Mezzanine Floor, Plot No 2, VIPPS Center, Local Shopping Complex, Masjid Moth, Greater Kailash-II, New Delhi 110048 in the building comprised of Basement, ground, Mezzanine plus Seven upper floors owner occupied by (A Unit of Fabulous Restaurant Pvt. Ltd) was issued fire safety certificate by this department vide letter no F6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 in the name of "M/s Smokey's Bbq & Grill Restaurant". The premise was inspected by the officer concerned of this department on 23/08/2021 in the presence of Mr. Nadim and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" Restaurant as above with effect from 27 / 8 /2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27 / 8 /2021 at New Delhi by



**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER**



Copy to: -

1. The Dy. Health Officer, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi – 110016. (Ref. MHA Portal ID 2021073226424 dated 21-07-2021)
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-49.
3. M/s LIT, (A Unit of Fabulous Restaurant Pvt, Ltd) located at Ground & Mezzanine Floor, Plot No 2, VIPPS Center, Local Shopping Complex, Masjid Moth, Greater Kailash-II, New Delhi 110048

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

124

INSPECTION REPORT

1	Name & Address of the Building	M/s LIT, (A Unit of Fabulous Restaurant Pvt, Ltd) Plot No 2, VIPPS Center, Local Shopping Complex, Masjid Moth, Greater Kailash-II, New Delhi 110048		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant at Ground Floor & Mezzanine Floor)		
3	Building comprised of	Basement, Ground, Mezzanine + Seven Upper Floor		
4	Type of Case	Old case (Name Change)		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 for the name of Smokey's Bbg & Grill		
6	Fire Safety Directives Letter No	UBBL-2016 / NBC Part-IV		
7	Date of Inspection	23.08.2021		
8	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Nadim		
10	Year of construction/ date of conversion	2006		
11	Applicant letter No.	Online Id 2021073226424 dated 21-07-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks
1	Access to Building.			
	• Road width	4.5m	Provided	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	2 Nos	02 no's	MR
	• Basement floor	-NA-	NA	-NA-
	b. Width of Staircase			
	• Upper floor	1.50m	1.50 m & 1.10 m	MR (Old case)
	• Basement floor	-NA-	NA	-NA-
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	-NA-	NA	-NA-
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	02 exit	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fan	M/A
5	Fire Extinguishers.			
	• Total numbers	06Nos	Provided	MR
	• Types	ABC / CO2	ABC-03& Co2-03	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hoofer's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	NA	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M/R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	150mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	01	provided	MR
	<ul style="list-style-type: none"> Hose box. 	01	provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	35m	38mtr	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	01	provided	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 Lpm	180 Lpm	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	35mtr	38mtr	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Pump House Access 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Power supply. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	50,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR


- M/26 -

18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	NA	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2021/40 dated 23/02/2021 for the name and Style of M/s Smokey's Bbq & Grill, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Rajesh Kumar
 Designation: ADO / BCP

~~DO (SD)~~

~~ADP~~
24/08/21

~~DO (SD)~~

F.T.


~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl.

~~DO (SD)~~



ADP
27/08/2021

~~ADO~~