

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 207

Dated: 2 / 9 /2021

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **Kampai** (A unit of Tasteshop Pvt. Ltd) located at Shop No G-02, Ground Floor, Asset-11, Worldmark-I, Aerocity, IGI Airport, New Delhi-110037, comprised of Three Basements, Mezzanine, Ground Floor & Six Upper Floors but the restaurant running at ground floor only was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/EH/2018/SZ/2666 dated 21/08/2021. The premise was re-inspected by the officers concerned of this department on 21/08/2021 in the presence of Mr. Shabbir (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises/building is fit for occupancy class "Assembly" (Group-D/Eating House) with effect from 2 / 9 /2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2 / 9 /2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, South Delhi Municipal Corporation, Public Health Department, Najafgarh Zone, Dhansa Stand, Najafgarh, New Delhi-110043
2. Authorized Signatory, M/s Kampai (A unit of Tasteshop Pvt. Ltd) at Shop No G-02, Ground Floor, Asset-11, Worldmark-I, Aerocity, New Delhi-110037

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Kampai (A unit of Tasteshop Pvt. Ltd), Shop No. G-02, Ground Floor, Asset-11, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037		
2	Type of Occupancy	Assembly "Group-D"		
3	Building comprised of	03 Basements, Mezzanine, Ground & Six Upper floors but the Restaurant is at GF only .		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2018/SZ/2666 dated 10/12/2018		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2017/Hotel/368 Dt. 21/02/2017 (Bldg)		
7	Date of Inspection	21/08/2021		
8	Name of the Inspecting Officers	DO (SD) & ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Shabbir (Manager)		
10	Year of construction	2014		
11	Applicant letter No.	Online ID-2021080516886 dated 05/08/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.	(FSC No. F.6/DFS/MS/Mixed/SZ/2021/09 dated 08/03/2021)		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restt located within Worldmark-1	As above As above As above	MR -NA- -NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- 02 Nos	As above As above	-NA- MR
	b. Width of Staircase	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- 2m/1.35m	As above <i>2m, 1.40m & 1.0m</i>	-NA- MR <i>(Cold case)</i>
	c. Protection of exits	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	As above As above	-NA- -NA-
	d. No. of continuous staircase to terrace	Required	As above	MR
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	2m/1.35m	2m, 1.40m & 1.06m	MR
3	Compartmentation.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required Required Required Required -NA-	As above As above As above As above As above	MR MR MR MR -NA-
4	Smoke Management system.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Basement Upper floors/Restt. Area 	-NA- Required	As above Smoke venting provided	-NA- -NA-
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	06 Nos. ABC / CO ₂ ISI marked	Provided ABC type Provided	MR MR MR
6	First Aid Hose Reels.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One 30m 5mm	As above As above As above	MR MR MR

7	Automatic fire detection & alarming system.	(Provided & Maintained by Bldg. Mgmt)		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hoofer's location 	-NA-	Smoke & Heat	-NA-
		-NA-	Mezzanine floor	-NA-
		-NA-	FCR at GF	-NA-
		-NA-	Provided	-NA-
		-NA-	All Area	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	As above	-NA-
10	Automatic Sprinkler System	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
11	Internal Hydrants.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
12	Yard Hydrants.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	As above	-NA-
		-NA-	As above	-NA-
13	Pumping arrangements.	Pumping arrangements are common for complex		
	<ul style="list-style-type: none"> Ground Level 	Provided & Maintained by Bldg. Mgmt		
	➤ Discharge of main pump.	-NA-	2280 LPM	-NA-
	➤ Head of main pump.	-NA-	105m	-NA-
	➤ Number of main pumps.	-NA-	Two	-NA-
	➤ Jockey Pump output.	-NA-	2 x 180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	105m	-NA-
	➤ Standby Pump output.	-NA-	2280 LPM	-NA-
	➤ Standby Pump head.	-NA-	105m	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	<ul style="list-style-type: none"> Terrace Level 	Provided & Maintained by Bldg. Mgmt		
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for Fire Fighting.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	1,50,000 Ltrs	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
		10,000 Ltrs	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided & Maintained by Bldg. Mgmt		
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	550m ²	-NA-
		-NA-	6 th Floor	-NA-

19	Fire Control Room.	Provided & Maintained by Bldg. Mgmt		
	• Detector System Panel.	-NA-	As above	-NA-
	• Flow Switch Panel.	-NA-	As above	-NA-
	• PA system Panel.	-NA-	As above	-NA-
	• Battery backup	-NA-	As above	-NA-
	• Building floor plan	-NA-	As above	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	As above	-NA-

Covered area of the restaurant is 213.36 m² and as per NBC (Part-IV) the number of occupant load comes out to approx. 142 persons (213.36/1.8=142.24). Thus the capacity of restaurant is 142 persons, which is covered under DFS Act 2007, Rules 2010. Accordingly, inspection of Eating House is carried out as per NBC (Part-IV).

The Fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The main building has been issued FSC by this department vide letter No. F.6/DFS/MS/Mixed/SZ/2021/09 dated 08/03/2021.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued in the name of vide letter No. F.6/DFS/MS/EH/2018/SZ/2666 dated 10/12/2018, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S.K. Dua
22/08/21

Signature of the Inspecting Officer
Name : S.K. Dua
Designation: DO (SD)

Ashok Kumar Jaiswal
23/8/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: ADO (SJ)

DCFO (SZ)

h *F.T.*
DO S.D.

F.T. letter is put up for sig/pl.

S.K. Dua
01/09/21

DCFO (SZ)

h
M.S. cell