

F1
C-55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/SZ/2021/ 706

Dated: 3/9/21

FIRE SAFETY CERTIFICATE

Certified that **Mararishi Dayanand Public School** located at **2580, Arya Samaj Mandir, Shadipur Khampur, Mandir Wali Gali, opp. West Patel Nagar, New Delhi-110008** comprised of ground plus three upper floors, having total 24 rooms (including class rooms, office, computer room, sports room, library, staff room & store room etc.) was issued FSC by this department vide letter No. F.6/DFS/MS/School/SZ/2017/253 dated 23.02.2017. The school building was re-inspected by officer concerned of Delhi Fire Service on 19.08.2021 in the presence of Mr. Neeraj Mendiratta, principal of the school and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 20007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 3/9/21 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed back side.

Issued on 3/9/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)

Copy to: -

1. The Principal, Mararishi Dayanand Public School, 2580, Arya Samaj Mandir, Shadipur Khampur, Mandir Wali Gali, opp. West Patel Nagar, New Delhi-110008.
2. The Directorate of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

1. Name & address of the building : Maharishi Dayanand Public School, 2580, Arya Samaj Mandir, Shadipur Khampur, Mandir Wali Gali, opp. West Patel Nagar, New Delhi-110008

2. Type of Occupancy : Educational

3. Type of Case : Renewal

4. Details of previous NOC : F.6/DFS/MS/School/SZ/2017/253 dated 23.02.2017

5. Fire Safety directives letter No : N/A

6. Date of inspection : 19.08.2021

7. Name of the Inspecting Officers : P.V Rathee, Asstt. Div. Officer (SRD)

8. Name and designation of officers from the building side : Mr. Neeraj Mendiratta, (Principal)

9. Year of Construction : Before 2007

10. Applicant's letter No. : Ref- 149/MDPS/SHADIKHAMPUR/2021-22 dated 08.07.2021

School building is comprised of ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	4.5 mts	4.5 mts	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.25 mts each	1.25, 1.20 mts	MR being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	1.5 mts.	Provided (2.35 mts)	MR
	h. Door Size	1.0 mt.	0.98 mt.	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Vent.	MR
5	Fire Extinguishers			
	• Total numbers	16 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	Not required	Provided (100 mm)	----
	• Number of hydrants per floor	Not required	Provided (01 No)	----
	• Hose Box	Not required	Provided (01 No)	----
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Not required	Provided	----
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 lts	Provided	MR being old case
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect. Panel.	MR

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

All the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/GH/SZ/2021/151 dated 23.03.2021 have been complied with by the school management.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2017/253 dated 23.02.2017, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

[Signature] 23/8/21

(P.V. Rathee)
Asstt. Div. Officer, (SRD)

[Signature] D.O. (SW)

[Signature] 24/08/2021

[Signature] Dy. C.O. / S2

[Signature] F. / r

[Signature]

ADD SRD