

C-26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2021/SZ/ 13

Dated: 03/09/2021

**FIRE SAFETY CERTIFICATE**

Certified that MCA Institute located at Banarsidas Chandiwala Institute of Information Technology (BCIIT) at B -Block, Banarsidas Chandiwala Estate, Maa Anandmai Marg, Kalkaji, New Delhi-110019 comprised of Block B- Basement (not in used under lock & key)+ Lower Ground Floor ( Sealed by MCD) + Upper Ground Floor + First Floor only was inspected by officer concerned of this department on 26/08/2021 in presence of Dr. Ravish Saggar (Director) and found that said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational Building" Group-B, (For Ground and First Floor only) with effect from the date of issue of this certificate for period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 03/09/2021 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

Copy to: -

1. Dr. Ravish Saggar (Director) The MCA Institute, Banarsidas Chandiwala Institute of Information Technology (BCIIT) at B -Block, Banarsidas Chandiwala Estate, Maa Anandmai Marg, Kalkaji, New Delhi-110019

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
7. **The FSC is valid for only Ground and First Floor only.**

N1)

### INSPECTION REPORT

1	Name & Address of the Building	MCA Institute located at Banarsidas Chandiwala Institute of Information Technology (BCIIT) at B - Block, Banarsidas Chandiwala Estate, Maa Anandmai Marg, Kalkaji, New Delhi-110019.		
2	Type of Occupancy	Educational, Group-B		
3	Building Comprised of	Block B- Basement (not in used under lock & key)+ Lower Ground Floor ( Sealed by MCD) + Upper Ground Floor + First Floor only		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	NBC Part- IV		
7	Date of Inspection	26/08/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Dr. Ravish Sagar (Director)		
10	Year of construction	Prior. To 1979		
11	Applicant letter No.	Gmail dated 25-08-2021		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC Part -IV</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	Access to Building.			
	Road width	6 mtr	6 mtr	MR
	Gate width	-NA-	5 mtr	-NA-
	Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	Number of Staircase			
	Upper floors.	02	Provided	MR
	Basement floor.	NA	Provided (Not in used)	NA
	Width of Staircase			
	Upper floors	1.5 m each	Provided	MR
	Basement floor	NA	1.5 mtr (Not in used)	NA
	Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	Pressurization	-NA-	-NA-	-NA-
	No. of continuous staircase to terrace	02 Nos.	02 Nos. Provided	MR
	Width of corridor	-NA-	-NA-	-NA-
	Door size	1m	Provided	MR
3	Compartmentation.			
	Fire check door.	-NA-	-NA-	-NA-
	Sealing of electrical shafts.	-NA-	-NA-	-NA-
	Fire rating of shaft door.	-NA-	-NA-	-NA-
	Water curtain	-NA-	-NA-	-NA-
	Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	Basement	-NA-	-NA-	-NA-
	Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	Total numbers	10 Nos	12 Nos	MR

N/2


	Types ISI Marking	ABC / CO2	ABC / CO2	MR
		ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	01 Nos.	01 Nos.	MR
	Length of hose-reel hose.	30 m	30 m	MR
	Nozzle Diameter	05 mm	05 mm	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	-NA-	Provided	-NA-
	Location of Main Panel	-NA-	-NA-	-NA-
	Location of Repeater Panel	-NA-	-NA-	-NA-
	Alternate source of power	-NA-	-NA-	-NA-
	Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	Basement	NA	Not in use	-NA-
	Upper floors	-NA-	Provided	-NA-
	Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	01 Nos.	Provided	MR
	Hose box.	01 Nos.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	NA	Provided	NA
	Hose box.	NA	Provided	NA
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	-NA-	-NA-	-NA-
	Head of main pump.	-NA-	-NA-	-NA-
	Number of main pumps.	-NA-	-NA-	-NA-
	Jockey Pump output.	-NA-	-NA-	-NA-
	Jockey Pump head.	-NA-	-NA-	-NA-
	Standby Pump output.	-NA-	-NA-	-NA-
	Standby Pump head.	-NA-	-NA-	-NA-
	Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	Pump house access.	-NA-	-NA-	-NA-
	Terrace Level			
	Discharge of pump.	900 LPM	Provided	MR
	Head of pump.	40 m	40 m	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	-NA-	-NA-	-NA-
	Draw-off connection.	-NA-	-NA-	-NA-
	Fire Service Inlet.	-NA-	-NA-	-NA-
	Access to tank.	-NA-	-NA-	-NA-
	Overhead tank capacity.	20,000 Ltrs.	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	Pressurization of lift shaft.	-NA-	-NA-	-NA-
	Pressurization of lift lobby.	-NA-	-NA-	-NA-
	Communication in lift car.	-NA-	-NA-	-NA-
	Fireman's switch.	-NA-	-NA-	-NA-
	Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	DG Set Provided	MR
18	Refuge Area			
	Total area	-NA-	-NA-	-NA-
	Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	Detector system panel.	-NA-	-NA-	-NA-
	Flow switch panel.	-NA-	-NA-	-NA-
	PA system panel.	-NA-	-NA-	-NA-
	Battery backup.	-NA-	-NA-	-NA-
	Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-


The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.


Accordingly DFA is put up for approval and signature please.

  
 Signature of Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Design: ADO (BCP)

DO (SD) — on leave

Dy C.F.O.   
27/8

C.F.O. (on duty)

Director (M)   
27/8/2021

FTPS

~~ADD/BLP~~

AS approved, F.T. letter is put up for your signature