

C19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F6/DFS/MS/EH/2021 / 211

Dated: 3 / 9 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Shivam Foods located at Ground and First floor, B-79, G.T. Karnal Road, Industrial Area, Delhi-110033 in the building comprised of Basement + Ground + 02 Floors owned/ occupied by M/s Shivam Foods was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2018/WZ/992 dated 10.05.2018. The premises was re-inspected by the officers concerned of this department on 25.08.2021 in the presence of Sh. Vijay Kr. Ohri and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building/ premise is fit for occupancy Class- "D" (Assembly) Restaurant at ground and first floor only occupancy with effect from... 31.9.21..... for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 31.9.21..... at New Delhi by

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph. No. 011-23414250

*[Handwritten signature and date 31/9/2021]*

Copy to:-

1. The Manager, M/s Shivam Foods at Ground and First floor, B-79, G.T. Karnal Road, Industrial Area, Delhi-110033
2. The Dy. Health Officer, NDMC, Public Health Department City S.P.Zone, Old Hindu College, Kashmere Gate, Delhi.
3. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.

**Conditions for the validity of Fire Safety Certificate:**

1. This Fire Safety Certificate is valid only Ground and First floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building :M/s Shivam Foods, B-79, GTK Road, Ind Area, Delhi
2. Type of Occupancy : (Assembly) Restaurant
3. Type of Case :Renewal (B+G+2 Upper floor)
4. Details of previous NOC :F6/DFS/MS/2018/WZ/992 Dated 10.05.2018
5. Fire Safety directives letter No : NBC Part IV Basement-Vacant
6. Date of inspection : 25.08.2021 **Ground- Restaurant**
7. Name of the Inspecting Officers : ADO (RN) **First floor- Restaurant**
8. Name and designation of officers : Mr. Vijay Kr. Ohri Second floor- Vacant  
from the building side
9. Year of Construction :2006
10. Applicant's letter No. : Online Portal I.D No- 2021071715373 Dated 24.07.2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	06m	06m	MR
	<ul style="list-style-type: none"> <li>• Gate width</li> </ul>	Directly Accessible	Directly Accessible	MR
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	1.5m each	Provided	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	B/M closed	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Two exits	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10nos	16nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/Co2	ABC-04/ WCo2-06 & Co2- 06	MR
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01	01	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180lpm	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul> </li> </ul>	900lpm	Provided	MR

	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10,000ltr	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	Required	Provided (GF)	MR
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety vide this department letter of even no.992 dated 10.05.2018 Certificate under rule 37(3) of Delhi Fire Service Rules 2010.

DO (NW)  
 26/08/2021  
 31/07/2021

Signature of the Inspecting Officer  
 Name: - C.L. Meena  
 Designation:- ADO/RN