

C-28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 697

Dated: 2 / 9 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029** comprised of Basement, Ground plus Three Upper Floors (one block) and Ground plus Two upper floor (one block) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2463 Dated 01/11/2018. The said premises was re-inspected by officer concerned of this department on 25/08/2021 in presence of SI Salim (Admin Officer) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 2 / 9 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 2 / 9 / 2021 at New Delhi by

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/10

### INSPECTION REPORT

1	Name & Address of the Building	Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi 110029		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	B+G+3 (One Block) & G+2 (One Block)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/2463 Dt. 01/11/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25-08-2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	SI Salim (Admin Officer)		
10	Year of construction	1998		
11	Applicant letter No.	Gmail Dated 03/08/2021		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Required	12 mtr	MR
		Required	05 m	MR
		-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors.</li> <li>➤ Basement floor.</li> </ul>	02 No's at each block	A Block- 02 B Block- 05	MR
		02 No's	05 Nos	MR
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors</li> <li>➤ Basement floor</li> </ul>	1.50 mtr each	A Block- 1.80 m each B Block- 1.80m, 1.31m x 2, 1.08m x 2 2.3m, 1.2m, 2.8m, 0.97m & 1.31 m	MR
		1.50 mtr each		MR
	<b>c) Protection of exits</b>			
	<ul style="list-style-type: none"> <li>➤ Fire check door</li> <li>➤ Pressurization</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	1.5 m	Provided	MR
	<b>f) Door size</b>	1 mtr	1 mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	30 ACPH	Exhaust fan Provided	MR
		12 ACPH	-NA-	-NA-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	Required	48 Nos	MR
		ABC	ABC Type	MR
		ISI mark	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	03 Nos	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR





<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2463 Dt. 01/11/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*[Handwritten Signature]*  
26/08/21

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

~~DO (SD)~~

*[Handwritten Signature]*  
26/08/21

~~DFO (SZ)~~

*[Handwritten Signature]*  
F.T.

~~ADO (B.C.P.)~~

As approved, F.T. letter is put up for your signature pl

*[Handwritten Signature]*  
27/10/2021

*[Handwritten Signature]*  
*[Handwritten Signature]*

M.S. cell