

C-25

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 707

Dated: 3/09/2021

FIRE SAFETY CERTIFICATE

Certified that the building Basava International School Located at Plot No. 1, Sector 23, Dwarka, New Delhi – 110075 comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/512 Dated 27/03/2018. The premises was re inspected by the officers concerned of this department on 05/08/2021 in the presence of Smt. Poornima Ambli (General Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class-B “Educational” with effect from 3/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on3/9/21..... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Smt. Poornima Ambli (GM), Basava International School Located at Plot No. 1, Sector 23, Dwarka, New Delhi – 110075
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/14
INSPECTION REPORT

1. Name & address of the building: Basava International School Located at Plot No. 1, Sector 23, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/512 Dated 27/03/2018
5. Fire Safety directives Letter No. : ..
6. Date of inspection : 05/08/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
 - a. from the building side : Smt. Poornima Ambli (General Manager)
9. Year of Construction : 2004
10. Applicant's letter No. : Email Dated-21/05/2021

Total Area = 4 acres.
Covered Area = 1.5 acres
Class rooms =
No. of students = 1630

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/8	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr 4.5 mtr NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	03 Nos. NA	03 Nos. NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.5 mtr NA	Provided NA	MR(Old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	02 Nos.	03 No.	MR
	e. Width Of Corridor	1.5 mtr	1.5mtr to 2.35 mtr	MR
	f. Door Size	1 mtr	1.05 to 1.10 mtr	MR(Old Case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltr	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/512 Dated 27/03/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *Asst Dy Insp*

DO/SZ

13/08/2021
By cfo/sz

F.F.

A O (DWR)