

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F6/DFS/MS/GH/2021/ 364

Dated 7/09/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/s Blue Umbrella Guest House** located at **A-20, Dhaka Village, Main Road, Kingsway Camp, Delhi-110033** comprised of ground plus three upper floors owned/ occupied by **Suman Rallan** was issued fire safety certificate vide letter no. **F6/DFS/MS/GH/2018/2024** dated **04.09.2018**. The premises was re-inspected by the officer concerned of Fire Service on **24.08.2021** in the presence of **Sh. Bharat Bhushan** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under rule 33 of Delhi Fire Service Rules, 2010 and the building is fit for occupancy **Class – Residential (Rooming & Lodging) for total 25 guest rooms (2nd floor- 12 guest rooms & 3rd floor- 13 guest rooms only)** with effect from ~~7/9/21~~ for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7/9/21 at New Delhi by

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph-011-25156707

ole kop

Copy to:-

1. The Addl. Commissioner of Police/ Lic, 1st Floor, Police Station, Defence Colony, New Delhi.
2. The Manager, M/s Blue Umbrella Guest House located at A-20, Dhaka Village, Main Road, Kingsway Camp, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Blue Umbrella Guest House at A-20, Dhaka Vill, Main Road, Kingsway Camp, Delhi-110033.
2. Type of Occupancy : Residential
3. Type of Case : Renewal (G+03 upper floor)
4. Details of previous NOC : F6/DFS/MS/GH/2018/2024 dated : 04.09.2018
5. Fire Safety directives letter No : As per BBL & NBC Part IV
Ground floor- Vacant
6. Date of inspection : 24.08.2021
First floor- Vacant
7. Name of the Inspecting Officers : ADO (RN)
Second floor-12 guest rooms
8. Name and designation of officers : Sh. Bharat Bhushan
Third floor-13 guest rooms
from the building side
9. Year of Construction : 2007
10. Applicant's letter No. : Online E-Mail Dated: 13.08.2021

Plot Area-450sqy

	Minimum Standards on fire prevention and fire safety U/R 33	BBL & NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	09m	MR
	• Gate width	06m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m & 1.05	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required NA	Provided NA	MR NA
	• Pressurization	01	01	MR
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1m	1m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	ABC & Co2	08- ABC & 02- Co2	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required(carbon monoxide)	Provided(carbon monoxide)	MR
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000ltr	5,000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	80 KVA	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note:- The compliance of the provision contained as per gazette notification no. F.5(189)/AD/LB/2016/4053-67 dated 27.05.2019 has been complied

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 2024 dated 04.09.2018 under rule 37 of the Delhi Fire Service Rules 2010.

DO (W)

Signature
01/09/2021
Signature (W2)

Signature
21/9/2021

Signature
25/8/2021

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation:- ADO/RN