GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110001

No.F.6 DFS/MS/School/2021/SZ/ 7/9

Dated: 7/9/2021

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya New Friends Colony, New Delhi 110025 (ID 1925033) comprised of Old Block, Ground + Two upper floor & New Block, Ground + Three upper floor was Safety Certificate by this department letter F6/DFS/MS/School/2017/SZ/1663 Dt. 16/11/2017 NOC for old block- (G +1 & G +2) New Three Blocks (G + 3). The said premises was re-inspected by officer concerned of this department on 11/12/2020 in presence of Mrs. Indra Sagar (Vice-Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and new school blocks in accordance with rule 33 of Delhi Fire Service Rules, 2010, and that the building is fit for occupancy class "Educational Building **Group – B"** with effect from $\frac{7}{9}$ / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 7 / 3 2021 at New Delhi by

(SUNIL CHAWDHARY) DY. CHIEF FIRE OFFICER (SZ) DELHI FIRE SERVICE

Copy to: -

- The Principal, Sarvodaya Kanya Vidyalaya New Friends Colony, New Delhi 110025 (ID 1925033)
- 2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

- 1. All the means of escape/entry/exit shall be kept free from any obstruction.
- 2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3. All the staff members must know the correct method of operation of firefighting system.
- 4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

alla

INSPECT	ION REPORT			
Name & Address of the Building	M/s Sarvodaya Kanya Vidyalaya New Friends Colony,			
	New Delhi 110025 (ID 1925033)			
	Educational, Group-B (School)			
Building Comprised of	Girls School Separate blocks, Girls School Comprised of Old Block G +2 & New Block G +3			
Type of Case		to reversion, G 15		
Details of Previous NOC	F6/DFS/MS/School/2017/SZ/1663 Dt. 16/11/2017 NOC for old			
Fire Safety Directives Letter No			101.03.2011	
Date of Inspection	28/08/2021			
Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)			
Name & Designation of Officers Mrs. Indra Sagar (Vice- Principal)				
	1989 & 2016			
	Gmail Dated 17/08/2021			
The state of the s	NBC/BBL	Provided at Site	Remarks	
and Fire Safety U/R 33	Requirement	V	MR/NMR	
Access to Building.				
Road width	6 mtr	9 mtr	MR	
Gate width	-NA-	4 mtr	-NA-	
Width of internal road	-NA-	-NA-	-NA-	
Number, width, type & arrangement of exits.				
a) Number of Staircase			-	
Upper floors.	Old block-2 Nos New Block-2 Nos	Old block-2 Nos New Block-2 Nos	MR	
Basement floor.	-NA-	-NA-	-NA-	
b) Width of Staircase				
	1.50 m / 0.75 m	Old block-1.25 mtr each	MR	
		New Block-1.84 mtr each	Old case	
	-NA-	-NA-	-NA-	
		-NA-	-NA-	
	-NA-	-NA-	-NA-	
	Required	Old block-1 & N. Block – 2	MR	
	-NA-	-NA-	-NA-	
f) Door size	1 mtr	1 mtr	MR	
Compartmentation.	1.1.2			
 Fire check door. 	-NA-	-NA-	-NA-	
 Sealing of electrical shafts. 	-NA-	-NA-	-NA-	
 Fire rating of shaft door. 	-NA-	-NA-	-NA-	
Water curtain	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
Smoke Management system.				
Basement	-NA-	-NA-	-NA-	
 Upper floors 	-NA-	-NA-	-NA-	
Fire Extinguishers.				
Total numbers	30 no's	30 Nos	MR	
 Types 	ABC / co2	ABC & co2 Type	MR	
	ISI mark	Provided	MR	
ISI Marking			1124	
First Aid Hose Reels.				
First Aid Hose Reels.	Old BK- 01 nos,	D	3 57	
First Aid Hose Reels. Total numbers on each floor.	N. BK- 02 Nos	Provided	MR	
First Aid Hose Reels. Total numbers on each floor.		Provided Provided Provided	MR MR	
	Name & Address of the Building Type of Occupancy Building Comprised of Type of Case Details of Previous NOC Fire Safety Directives Letter No Date of Inspection Name of the Inspecting Officers Name & Designation of Officers from the building side Year of construction Applicant letter No. Minimum standards on Fire Prevention and Fire Safety U/R 33 Access to Building. Road width Gate width Width of internal road Number, width, type & arrangement of exits. Number of Staircase Upper floors Basement floor b) Width of Staircase Upper floors Basement floor c) Protection of exits Fire check door Pressurization d) No. of continuous staircase to terrace e) Width of corridor f) Door size Compartmentation. Fire check door Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. Smoke Management system. Basement Upper floors Fire Extinguishers. Total numbers	Type of Occupancy Building Comprised of Girls School Sept of Old Block, G-Menewal Details of Previous NOC Fire Safety Directives Letter No Date of Inspection Name of the Inspecting Officers Name & Designation of Officers Offi	Name & Address of the Building	

NV

		NIA	-NA-	-NA-
	Type of detectors	-NA-	-NA-	-NA-
	Location of Main Panel	-NA-	-NA-	-NA-
	Location of Repeater Panel	-NA-	-NA-	-NA-
	Alternate source of power	-NA-	-NA-	-NA-
	Hooter's location	-NA-	-NA-	-NA-
. N	MOEFA	-NA-	-NA-	-NA-
	Public Address System	-NA-	-INA-	1421
	Automatic Sprinkler System		-NA-	-NA-
	Basement	-NA-	-NA-	-NA-
	Upper floors	-NA-		-NA-
	Sprinkler above false ceiling	-NA-	-NA-	-1V/X-
1.]	Internal Hydrants.			-NA-
1.	Size of Riser/Down-comer	-NA-	-NA-	-NA-
	Number of Hydrant per floor	-NA-	-NA-	
	Hose box.	-NA-	-NA-	-NA-
12	Yard Hydrants.			27.4
12.	1 1 (1 1	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Hose box.	and the same of th		
13.	Pumping arrangements.			
_	Ground Level	-NA-	-NA-	-NA-
	Discharge of main pump.	-NA-	-NA-	-NA-
	Head of main pump.	-NA-	-NA-	-NA-
	Number of main pumps.	-NA-	-NA-	-NA-
	Jockey Pump output.	-NA-	-NA-	-NA-
	Jockey Pump head.	-NA-	-NA-	-NA-
	Standby Pump output.	-NA-	-NA-	-NA-
	Standby Pump head.	A STATE OF THE PARTY OF THE PAR	-NA-	-NA-
	Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	Pump house access.	-NA-	-1477	
	Terrace Level	Old BK 450 LPM	Provided	MR
	Discharge of pump.	N.B- 450 LPM		MR
		40 m	Provided	MR
	> Head of pump.	Required	Provided	-
	Power supply.	Required	Provided	MR
	Auto starting of pump.		25 1	
14.	Captive water storage for fire fighting.	-NA-	-NA-	-NA-
	Underground tank capacity.	-NA-	-NA-	-NA-
	Draw-off connection.	-NA-	-NA-	-NA-
	Fire Service Inlet.	-NA-	-NA-	-NA-
	Access to tank.Overhead tank capacity.	Old bk-10,000 ltrs New BK- 10,000 ltrs	Provided	MR
1 5	Exit Signage.	Required	Provided	MR
15.	Provision of Lifts.			
16.		-NA-	-NA-	-NA-
	- C1:O.1-bb	-NA-	-NA-	-NA-
	1:0	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA
	• Fireman's switch.	-NA-	-NA-	-NA
	Lift signage.	-NA-	-NA-	-NA
17.	Standby Power Supply	-14LY-	Activities and desired wheel helps and reason address are seen as the second and	
18.	Refuge Area	-NA-	-NA-	-NA
	Total area		-NA-	-NA
	• Location	-NA-	-NA-	-11/3
				dan and the same of the same o
19.	Fire Control Room.		Annual Control of the	

	Flow switch panel.	-NA-	-NA-	-NA-
	PA system panel.	-NA-	-NA-	-NA-
	Battery backup.	-NA-	-NA-	-NA-
	Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 212 dated 16/04/2021

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1663 Dt. 16/11/2017 NOC for old block- (G +1 & G +2) New Three Blocks (G + 3), renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer Name: Sh. Rajesh Kumar

Design: ADO (BCP)

As approved, F.T. Lotted in prul your synature Pl

Dy Golsp