

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No.F.6/DFS/MS/EH/2021/SZ/ 434

Dated: 07/09/2021

FIRE SAFETY CERTIFICATE

Certified that the Food Court is located at ground & first floor in a building comprised of basement, ground & first floor located at Dilli Haat Janakpuri, New Delhi. The premises have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of this department on 06/09/2021 in the presence of Sh. Kamlesh (AE) and found that the building (ground & first floor) is fit for occupancy 'Class D "Assembly Building"(Restaurant/Food Court) ' for with effect from 07/09/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 07/09/2021 at New Delhi by

  
(Atul Garg)  
Director

Delhi Fire Service

To,

M/s Executive Engineer (JP), DTTDC Ltd., Dilli Haat Janakpuri, New Delhi.

Following fire safety directives must be adhered to:-

- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- Basement shall not be used for any purpose.

N/1

**INSPECTION REPORT**

1. Name & address of the building : M/s Food Court Area in Dilli Haat, Janak Puri, New Delhi-110058
2. Type of Occupancy : Assembly Building (Proposed at ground & first floor)
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : F6/DFS/MS/BP/2011/2139 dated 02.09.2011
6. Date of inspection : 06/09/2021
7. Name of Inspecting Officer : A.D.O. R.K.Yadav
8. Name and designation of officers  
From the building side : Sh. Kamlesh (AE)
9. Year of Construction : 2014
10. Applicant's letter No. : F.no.23(03)/DTTDC/Engg./EE(E)/2021-22/171 dated 24/08/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12 mtrs 4.5 mtrs N/A	18 mtrs Provided N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	2 Staircase + 1 Ramp	Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	3 Staircase+2 Ramp	Provided	MR
		2 m & 1.5 m & 2 m ramp	Provided	MR
		2X2 m & 1x 1.8 m & 4.5 M Ramp	Provided	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required	Provided	MR
		Required	Provided	MR
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1 Staircase + 1 Ramp	Provided	MR
	f. Door Size	2.0 m & 1.50 m	Provided	M/R
		2.0 m	2 m each Provided	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		Required	sealed	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	15 no.'s	Provided	MR
		W/CO <sub>2</sub> / CO <sub>2</sub> type	Provided	MR
		ISI marked	Provided	MR



N/2

6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	2 No.	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors (smoke/heat)</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement (entire)</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Ground Floor &amp; upper floors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 MM	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	2 No.	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	2 No.	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	3 No.	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	3 No.	Provided	MR
13.	<b>Pumping Arrangements (Common for Delhi Haat Janakpuri)</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> </ul> </li> </ul>	2850 LPM & 2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>Head of Main pump</li> </ul>	60 mtrs	Provided	MR
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	Two	Provided	MR
	<ul style="list-style-type: none"> <li>Jockey Pump out put</li> </ul>	220 LPM & 180 LPM	180 LPM (02.no.'s)	MR
	<ul style="list-style-type: none"> <li>Jockey pump head</li> </ul>	60 mtrs	Provided	MR
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul>	2850 LPM & 2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul>	60 mtrs	Provided	MR
	<ul style="list-style-type: none"> <li>Auto Starting/Manual Stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> </ul> </li> </ul>	900 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Auto Starting of pump</li> </ul>	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting (Common for Delhi Haat Janakpuri)</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	2,00,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	25000 Ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR



16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	Manual operated CO <sub>2</sub> in HT & LT pannels	Provided	M/R

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures in accordance with the NBC of India (part-IV) it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of Inspecting Officer *R. K. Yadav* 6/9/2021  
 Name:- R.K.Yadav  
 Designation:- Asstt. Divisional Officer

DO (South West)

*K. Gupta*  
 06/09/2021  
 Dy cfo /s2  
 G.H.O.

*[Signature]*  
 6/9  
*[Signature]*  
 H.S.



CT PS