

c-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/MN/2021/ 219

Dated: 9/9/21

FIRE SAFETY CERTIFICATE

Certified that the **Cafeteria & Co. Unit of Jumbo Restaurants Project Ltd.** located at, **SH 2F 02A, 2nd Floor Pacific Mall, Najafgarh Road, Tilak Nagar, New Delhi** comprised of Two Basements, Ground & four upper floors plus Projection room. FSC to mall is issued vide letter no. F6/DFS/MS/2020/267 dated 22-07-2020. The premises was inspected by the officer concerned of this department on 26-08-2021 in the presence of Sh. Akhil Malik (Owner) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 9/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Printed below.

Issued on ...9/9/21... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
880
06/09/2021

Copy to:

1. Cafeteria & Co. Unit of Jumbo Restaurants Project Ltd. located at , SH 2F, 02A, 2nd Floor Pacific Mall, Najafgarh Road, Tilak Nagar, New Delhi
2. Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building : Cafeteria & Co. Unit of Jumbo Restaurants Project Ltd.
Located at, SH 2F 02A, 2nd Floor Pacific Mall, Najafgarh Road, Tilak Nagar, New Delhi
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 26.08.2021
7. Name of the Inspecting Officers : ADO(MN)
8. Name and designation of officers from the building side : Sh. Akhil Malik (owner)
9. Year of Construction : 2007 (As per MH portal)
10. Applicant's letter No. : Online application no. 20210762615950 dtd. 26/07/2021

* The said Restaurant is running on Second floor in Pacific Mall in a building comprised of two Basement, ground plus four upper floors & projection room was issued FSC vide Letter No. F6/DFS/ MS/ WZ/2020/267 dated 22/07/2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	30 m Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided by mall	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	Provided by mall	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.5 m each	2.8m & 1.68m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	03	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		30m	Provided	MR
		5m	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants	Common with Mall		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		NA	Common with Mall	NA
		900lpm	Common with Mall	NA
		40m	Common with Mall	NA
		Required	Common with Mall	NA
		Required	Common with Mall	NA
14	Captive Water Storage for fire fighting.			
	Common with Mall			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	20,00000 ltr	NA
		NA	Provided	NA
		Required	Provided	MR
		NA	Provided	NA
		10,000	30,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR

7-3

16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Flooding System is provide in kitchen wood & Electric Panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (yes)~~

[Signature]
27/8/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

[Signature]
28/8/2024

DCFO (W2)

[Signature]
31/8/2024

[Signature]

[Signature]
1/9

[Signature]

[Signature]
11/9/24
215

[Signature]
21/9/2024

[Signature]
31/8

[Signature]

