

C-44

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 222

Dated: 10/9 /2021

FIRE SAFETY CERTIFICATE

Certified that **KFC Restaurant, (A unit of Sapphire India Pvt Ltd) at J-23A, Lajpat Nagar-II, Delhi** comprised of Basement, ground plus three upper floors but the restaurant running at First and Second floor only was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/SZ/2018/2297 dated 11/10/2018. The restaurant premise was re-inspected by the officer concerned of this department on 01/09/2021 in the presence of Mr. Madhu (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from **10/9**...2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10 / 9 /2021 at New Delhi by



**SUNIL CHAUDHARY
DY. CHIEF FIRE OFFICER (SZ)**

Signature

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID No. 2021072916179 dated 01/08/2021)
3. KFC Restaurant, (A unit of Sapphire India Pvt Ltd) at J-23A, Lajpat Nagar-II, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	KFC Restaurant, (Sapphire India Pvt Ltd) at J-23A, Lajpat Nagar-II, Delhi		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, ground, plus 03 upper floors (restaurant running at 1 st & 2 nd floor only)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2018/2297 dated 11/10/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	01/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Madhu		
10	Year of construction	2009		
11	Applicant letter No.	MHA Portal ID No 2021072916179 dated 01/08/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant	6 mtr	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	02 N/A	02 N/A	MR N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	1.15 & 1.10 mtr N/A	Provided N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircase to terrace	01	02 Nos	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Exit	0.90 mtr & 0.97 mtr	MR (old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	N/A 12 ACPH	N/A Provided in kitchen	N/A MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	06 Nos ISI marked	06 Nos. ABC-04, W.CO ₂ -02 Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	Required 30m 5mm	Provided in 2 nd floor Provided Provided	MR MR MR
7	Automatic Fire Detection and Alarming system.			

N/S

	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter F6/DFS/MS/EH/SZ/2018/2297 dated 11/10/2018 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

AK
6/09/2021

Signature of the Inspecting Officer
Name : Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (South)

AK
06/09

DFS (S2)

F.T.

AK

AK

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

AK
9/9/2021

DFS (S2)

AK

M.S. Cell