

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ CNS/439

Dated: 10/09/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Filling Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi – 110075 comprised of Ground + 01 Upper Floor was issued NOC vide Letter No. F6/DFS/MS/CNG/2018/SZ/1227 dated- 24/05/2018. The premises was re inspected by the officers concerned of this department on 25/08/2021 in the presence of Mr. Devashish Sharma (D.M Fire & safety) & Mr. Satender Khushwaha (Technician) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Hazardous” (CNG filling station) with effect from 10/09/2021 for a period of three years.

Issued on 10/09/2021 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh.Ajay Khatri DGM – Fire & Safety Indraprastha Gas Limited New Delhi.
2. Mr. Devashish Sharma (D.M Fire & safety) M/s CNG Filling Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s CNG Filling Station (IGL) Located at Sector – 23 B, Phase-II, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground + 01 Upper Floor)
4. Details of previous NOC : F6/DFS/MS/CNG/2018/SZ/1227 dated- 24/05/2018.
5. Fire Safety directives L. No. :OISD179/F5/(3A)/DFS/CNG/BP/2012/1487
Dated 25/04/2012
6. Date of inspection : 25/08/2021
7. Name of the Inspecting Officer : Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Devashish Sharma (D.M Fire & safety) &
Mr. Satender Khushwaha (Technician)
9. Year of Construction : 2012
10. Applicant's letter No. :Email dated 23/08/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	9m	30 m		MR
	• Gate width	4.5m	Directly accessible from road		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	02	02		MR
	• Basements	NA	NA	NA	
	b. Width of staircases				
	• Upper floors	120cm & 70 cms	120cm & 70 cms		MR
	• Basements	NA	NA	NA	
	c. Protection of exits				
	• Fire check door	NA	NA	NA	
	• Pressurization	NA	NA	NA	
	d. No of continuous staircase to terrace	NA	NA	NA	
	e. Width Of Corridor	NA	NA	NA	
	f. Door Size	1 mtr	1.25 mtr		MR
3.	Compartmentation				
	• Fire check door	NA	NA	NA	
	• Sealing of electrical shafts	NA	NA	NA	
	• Fire Rating of shaft door	NA	NA	NA	
	• Water Curtain	NA	NA	NA	
	• Fire Dampers	NA	NA	NA	

N/16

12.	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power supply	NA	NA	NA
	➢ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:	NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	➢ Draw off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts	NA	NA	NA
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	NA	NA	NA
	➢ Fireman's Grounding	NA	NA	NA
	➢ Switch	NA	NA	NA
	➢ Lift Signage	Required	Provided DG set 25 kva	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	NA	NA	NA
	➢ Total area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➢ Detector system panel	NA	NA	NA
	➢ Flow Switch Panel	NA	NA	NA
	➢ PA System Panel	NA	NA	NA
	➢ Battery backup	NA	NA	NA
	➢ Building Floor Plans	NA	NA	NA

20. Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR
--	--------------	-------------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers7, 8 & no one on duty is found capable to operate CO2 Flooding/DCP flooding/Water mist foam Trolley.

Signature of the Inspecting Officer
 Name *Uday Singh*
 Designation *ADD/DWR*

Uday Singh

21/06/2021

Dy CPO (Sr)

Uday Singh

ADD/DWR

ADD/DWR

hire for letter is put up for

sign ple 12/06

Uday Singh