

C-36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/EH/SZ/2021/ 231

Dated. 14./9./2021

FIRE SAFETY CERTIFICATE

Certified that **The Golden Dragon Restaurant (A Unit of Universal Foods Pvt. Ltd) at 1st Floor DDA Market, Panchsheel Park, New Delhi -110016** running at 1st floor of the building comprised of Ground plus one upper floor was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2018/SZ/146 dated 23/01/2018. The restaurant premise was re-inspected by the officer concerned of this department on 09/09/2021 in the presence of Sh. Pawan Sachdeva (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 14./9./2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14 / 9 /2021 at New Delhi by



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Joint C.P (Lic) First Floor, PS Defence Colony, New Delhi – 110049.
2. The Dy. Health Officer, Health Department, South MCD, Green Park, New Delhi. (Ref. MHA Portal ID 2021072215618 dated 29-07-2021)
3. The Golden Dragon Restaurant (A Unit of Universal Foods Pvt. Ltd) at 1st Floor DDA Market, Panchsheel Park, New Delhi -110016

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

| 1 | Name & Address of the Building | Ms Golden Dragon Restaurant (A Unit of Universal Food Pvt. Ltd) at 1 st Floor DDA Market, Panchsheel Park, New Delhi -110016 | | |
|--------|---|---|---------------------|-----------------|
| 2 | Type of Occupancy | Assembly 'Group-D' (Restaurant running at first floor only) | | |
| 3 | Building comprised of | Ground plus one upper floor | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/EH/2018/SZ/146 dated 23/01/2018 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 09.09.2021 | | |
| 8 | Name of the Inspecting Officers | Rajesh Kumar/ ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Sh. Pawan Sachdeva (Manager) | | |
| 10 | Year of construction/ date of conversion | 2006 | | |
| 11 | Applicant letter No. | MHA Portal ID 2021072215618 dated 29-07-2021 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | As per old NOC | Provided at Site | Remarks |
| 1 | Access to Building. | | | |
| | • Road width | Required | 09 mtr | MR |
| | • Gate width | NA | NA | -NA- |
| | • Width of internal road | NA | NA | -NA- |
| 2 | Number, width, type & arrangement of exits | | | |
| | a. Number of Staircase | | | |
| | • Upper floors | Required | 1 + 1 ramp | MR |
| | • Basement floor | NA | NA | -NA- |
| | b. Width of Staircase | | | |
| | • Upper floors | Required | 0.72 & 1.25 ramp | MR |
| | • Basement floor | NA | NA | -NA- |
| | c. Protection of exits | | | |
| | • Fire check door | -NA- | NA | -NA- |
| | • Pressurization | -NA- | NA | -NA- |
| | d. No. of continuous staircase to terrace | -NA- | NA | -NA- |
| | e. Width of corridor | N/A | N/A | N/A |
| | f. Door size | 02 exits | 1.15 m & 1.20 m | MR (oldcase) |
| 3 | Compartmentation. | | | |
| | • Fire check door. | N/A | N/A | N/A |
| | • Sealing of electrical shafts. | N/A | N/A | N/A |
| | • Fire rating of shaft door. | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers. | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floors | 12 ACPH | Natural ventilation | MR |
| 5 | Fire Extinguishers. | | | |
| | • Total numbers | 04 Nos | 04 Provided | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6 | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | One | Provided | MR |
| | • Length of hose-reel hose. | 30m | Provided | MR |
| | • Nozzle Diameter | 5mm | Provided | MR |
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |

| | | | | |
|----|--|---------------|------------|------|
| | <ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hoofer's location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | -NA- | NA | -NA- |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement | -NA- | NA | -NA- |
| | <ul style="list-style-type: none"> Upper floors | Required | Provided | M/R |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser/Down-comer | 100mm | Provided | MR |
| | <ul style="list-style-type: none"> Number of Hydrant per floor | 01 | provided | MR |
| | <ul style="list-style-type: none"> Hose box. | 01 | provided | MR |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Hose box. | -NA- | -NA- | -NA- |
| 13 | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main pump. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Head of main pump. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Number of main pumps. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Jockey Pump output. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Jockey Pump head. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Standby Pump output. | N/A | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Standby Pump head. | N/A | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Pump House Access | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Terrace Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of pump. | 450 & 180 LPM | 450 LPM | MR |
| | <ul style="list-style-type: none"> ➤ Head of pump. | 40m | 35mtr | MR |
| | <ul style="list-style-type: none"> ➤ Power supply. | Required | Provided | M/R |
| | <ul style="list-style-type: none"> ➤ Auto starting of pump. | Required | Provided | M/R |
| 14 | Captive water storage for Fire Fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Draw-off connection. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> ➤ Fire Service Inlet. | Required | Provided | M/R |
| | <ul style="list-style-type: none"> ➤ Access to tank. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Overhead tank capacity. | 25,00 ltrs | 5,000 ltrs | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Pressurization of lift lobby. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Communication in lift car. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Fireman's switch. | -NA- | -NA- | -NA- |
| | <ul style="list-style-type: none"> Lift signage. | -NA- | -NA- | -NA- |
| 17 | Standby Power Supply | Required | Provided | MR |
| 18 | Refuge Area | | | |

2/15

| | | | | |
|----|--|------|------|------|
| | • Location | -NA- | -NA- | -NA- |
| 19 | Fire Control Room. | | | |
| | • Detector System Panel. | -NA- | -NA- | -NA- |
| | • Flow Switch Panel. | -NA- | -NA- | -NA- |
| | • PA system Panel. | -NA- | -NA- | -NA- |
| | • Battery backup | -NA- | -NA- | -NA- |
| | • Building floor plan | -NA- | -NA- | -NA- |
| 20 | Special Fire Protection System for the Protection of special Risk, if any : | -NA- | -NA- | -NA- |

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/146 dated 23/01/2018 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
10/9/2021

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

~~DO (SD)~~

Rimp
11/09/21

Devo (2)
←

12/1

Sh

A DO (P)

As approved, f.t. letter is put up for your signature pl

11/09/2021

Dy Chdler

Sh

10/9/21