

C-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 732

Dated: 9 / 9 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Public School**, Located at **Pushpanjali Enclave, Pitampura, Delhi-110034** comprised of **Ground + 02 Upper Floors** was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2018/WZ/2004 dated 31.08.2018. The said premise was re-inspected by the officer concerned of this department on 02.09.2021 in the presence of Dr. Renuka Kamal (Vice Principal) & Sh. Dinit Batra (Estate Officer) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E Cr. No. 3298-3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 9/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 9/9/21..... at New Delhi by.


9/9/2021
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Guru Nanak Public School, Pushpanjali Enclave, Pitampura, Delhi-110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

Pushpanjali Enclave, Pitampura, Delhi-110034

2. Type of Occupancy : Educational (Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC No. : F6/DFS/MS/School/2018/WZ/2004 Dated 31.08.2018
5. Fire Safety directives Letter No. : DOE Circular3298-3398 dated 01-03-2011
6. Date of inspection : 02-09-2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Dr. Renuka Kamal (Vice Principal) & Sh. Dinit Batra (Estate Officer)
9. Year of Construction : 1989
10. Applicant's letter No. : email dated 18.08.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cr-3298-3398 dated 01-03-2011/letter dated 31.08.2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6mtrs 4.5 mtrs 3 mtrs	12 mtrs 5 mtrs Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basement c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	2 NA 2x1.5mtr NA NR NR Required 2 mtrs 1mtr	4 NA 1x160cm,1x180cm,1x175cm & 1x110cm NA NR NR Provided Provided	MR NA MR NA MR MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NR	NR	NA
		NR	NR	NA
		NR	NR	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	Provided	NA
		NA	Provided	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm & 220 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 Ltrs.	15000 Ltrs.	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/School/2018/WZ/2004 Dated 31.08.2018 is recommended under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
3/9/21
S.P. Bhardwaj, ADO (WP)

~~DO/WZ~~

~~[Signature]~~
6/9/2021

~~DCFO (WZ)~~

~~[Signature]~~
19/9/2021

~~ADO/WZ~~

FT for Singla pu

~~Defo/WZ~~

~~[Signature]~~
9/9/2021

~~[Signature]~~
8/9/21

ms/cell

D.O. (WEST) 222
DATED.. 06/09/21