

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2021/ 445

Dated: 14/09/2021

FIRE SAFETY CERTIFICATE

Certified that the M/S ITPO Halls No. 7A, B, C, D, E, F, G, H, & 8, 9, 10, 11, 12 & 12-A along with auditorium above hall No 8 located at Mathura Road, New Delhi, comprised of ground plus one upper floor, owned/occupied by International Trade Promotion Organizer was granted FSC vide letter No F6/DFS/MS/NDZ/2019/04 dated 02.01.2019 & even no. 5301 dated 02.09.2019. Now, the premises was re- inspected by the officers concerned of this department on 02/09/21 in the presence of Sh. Amit Chikara , Dy Manager (electrical) Mr J. Rama Rao and other officers of ITPO and found that building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group D, Assembly building with effect from 14/09/2021.... for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 14/09/2021 at New Delhi by.


14/9/21

(Dr. S.K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Deputy General Manager International Trade Promotion organizer, Mathura Road, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The number of occupants/person in each hall shall not be allowed more than the occupant load as specified in UBBL/NBC part-4.

11/22

INSPECTION REPORT

1.	Name & address of the building	ITPO located at Mathura Road , New Delhi
2.	Type of occupancy:-	Assembly – group D Ground and one upper floor
3.	Type of case:-	Renewal
4.	Details of previous FSC:-	No. F6/DFS/MS/NDZ/2019/04 & even no 5303 on dated 02.01.2019 & 02.09.2019.
5.	Fire safety directives No.-	F6/DFS/MS/BP/2008/2872 dated 15.10.2008
6.	Date of inspection:-	02.09.2021
7.	Name of the inspecting officer:-	Sh. Ravinder Singh (ADO/CC) Sh. Rajinder Atwal , DO (CD)
8.	Name & designation of officer From the building side:-	<u>Mr, Amit Ckikara , Mr J Rama Rao and other officers</u>
9.	Year of construction:-	1982
10.	Applicant's letter No:-	e-mail < amitchhikara@itpo.gov.in dated 05.08.2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	13meter	18 mtr	MR
	2) Gate width	05 mtr	06 mtr	MR
	3) Width of internal road	06mtr	09 mtr	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	06 Nos.	06 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	2.0m each	2.0m each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.	02 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A

N/L²

	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			N/A
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural/exhaust	MR
5.	Fire Extinguishers			
	1) Total numbers	280 Nos.	360 Nos.	MR
	2) Types	ABC & CO ₂	ABC & CO ₂	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of hose reel	44nos	44nos	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors, smoke	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	At each hall	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	Provided	MR
	2) Number of hydrants per floor	32nos	35nos	MR
	3) Hose box	32nos	35nos	MR
12.	Yard Hydrants			
	1) Total number of hydrants	30 Nos	35 Nos	MR
	2) Hose box	30 Nos	35Nos	MR
13.	Pumping Arrangement			
	Ground level	Required	Provided	MR
	a) Discharge of main pump	2850LPM	2850LPM	MR
	b) Head of main pump	70 m	70 m	MR
	c) Number of main pump	02 nos	02 nos	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 m	70 m	MR
	f) Stand by pump output	2850LPM	2850LPM	MR
	g) Stand by pump head	70 m	70 m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			

	a) Discharge of pump	N/A	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting				
	a) Under ground tank capacity	1,00,000 L	2,00,000 liter	MR	MR
	b) Draw-off connection	Required	Provided	MR	MR
	c) Fire service inlet	Required	Provided	MR	MR
	d) Access to tank	Required	Provided	MR	MR
	e) Over head tank capacity	N/A	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR	MR
16.	Provision of Lifts.				
	a) Pressurization of lift shaft	N/A	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR	MR
	d) Fireman's switch	Required	Provided	MR	MR
	e) Lift signage	Required	Provided	MR	MR
17.	Stand by Power Supply	Required	Provided	MR	MR
18.	Refuge Area	N/A	N/A	N/A	N/A
	a) Total area location	N/A	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR	MR
	a) Detector system panel	Required	Provided	MR	MR
	b) Flow switch panel	Required	Provided	MR	MR
	c) PA system panel	Required	Provided	MR	MR
	d) Battery backup	Required	Provided	MR	MR
	e) Building floor plan	Required	Provided	MR	MR
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO²				

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/NDZ/2019/04 & even No. 5303 on dated 02.01.2019 & 02.09.2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the inspecting officer


Signature of the Inspecting Officer

Name: - Rajinder Atwal
Designation: - DO (CD)

Name: Ravinder Singh
Designation: ADO (CC)

Dy. Insp. (Ops) F. A. P. I.

Rajinder Atwal
21/5/21



As approved for permit for fire
As approved for permit for fire
As approved for permit for fire