

C-52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2021/ 229

Dated. 14/09/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Locale (A Unit of Foursome Foods Pvt Ltd.) Shop No 17, Community Centre, Saket, New Delhi 110017 comprised of Basement Ground plus Three Upper Floors (Restt. running on Second & Third Floor) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2018/SZ/806 dated 24/04/2018. The restaurant premise was re-inspected by the officer concerned of this department on 06/09/2021 in the presence of Sh. Gurbinder Singh of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" Restaurant as above with effect from 14/09/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/9/2021 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Joint C.P (Lic) First Floor, PS Defence Colony, New Delhi - 110049.
2. The Dy. Health Officer, Health Department, South MCD, Green Park, New Delhi- 110016 (Ref. MHA Portal ID No 2021072916240 dated 29-07-2021)
3. M/s Locale (A Unit of Foursome Foods Pvt Ltd.) Shop No 17, Community Centre, Saket New Delhi 110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Locale (A Unit of Foursome Foods Pvt Ltd.) Shop No 17, Community Centre, New Delhi 110017		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant at Second and Third Floor only)		
3	Building comprised of	Basement, Ground Plus Three Upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2018/SZ/806 dated 24/04/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	06.09.2021		
8	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Gurvinder Singh		
10	Year of construction/ date of conversion	1988		
11	Applicant letter No.	MHA Portal Id 2021072916240 dated 29-07-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks
1	Access to Building.			
	• Road width	9 m	24 m Provided	MR
	• Gate width	Required	1.5 mtr restaurant gate provided	MR
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	01 Nos	01 Nos	MR (old case)
	• Basement floor	01 Nos	01 Nos	MR (old case)
	b. Width of Staircase			
	• Upper floors	1.25m	1.19 mtr	MR (Old Case)
	• Basement floor	1.25m	1.19 mtr	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	Required	01 No Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.5 mtr	1.5 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fan	M/A
5	Fire Extinguishers.			
	• Total numbers	12 Nos	Provided	MR
	• Types	ABC / CO2	ABC-06& Co2-06	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided at second & Third Floor	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooper's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> • Number of Hydrant per floor 	01	provided	MR
	<ul style="list-style-type: none"> • Hose box. 	01	provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Pump House Access 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM & 180 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Overhead tank capacity. 	5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> • Pressurization of lift lobby. 	N/A	-NA-	-NA-
	<ul style="list-style-type: none"> • Communication in lift car. 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's switch. 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift signage. 	N/A	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			

17/19

	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector System Panel. Flow Switch Panel. PA system Panel. Battery backup Building floor plan 	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/806 dated 24/04/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
31/5/2019

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (South)

Ring
15/05/19

F.T.

Dufo (S)

[Handwritten signature]

ADO/BCP

As approved, F.T. letter is put up for your signature pl

RK
14/5

Dufo (S)

[Handwritten signature]

M.S.