

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2021/SZ/ 746

Dated: 15/9/21

**FIRE SAFETY CERTIFICATE**

Certified that the building of **New Age Public School**, 12, Gupta Enclave, Vikas Nagar, Main Ranholla road, New Delhi-110059, comprised of ground floor only, owned/occupied by Ahoram Tyagi Memorial Educational Society (Regd.) was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2018/SZ/2118 dated 25/09/2018. The School building was re- inspected by the officer concerned of this department on 06/09/2021 in the presence of Sh. Gaurav Tyagi (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 15/9/21 ..... at New Delhi.

  
(SUNIL CHAUDHARY)  
DY.CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Principal,  
New Age Public School, 12, Gupta Enclave,  
Vikas Nagar, Main Ranholla road, New Delhi-110059.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



N/11

**INSPECTION REPORT**

- 1. Name & address of the building : New Age Public School, 12, Gupta Enclave, Vikas Nagar, Main Ranholla road, New Delhi-110059.
- 2. Building comprised of : Ground floor only
- 3. Type of Occupancy : Educational
- 4. Type of Case : Renewal
- 5. Details of Previous NOC : F.6/DFS/MS/School/2018/SZ/2118 dated 25/09/2018.
- 6. Fire Safety directives letter No : N/A
- 7. Date of inspection : 06/09/2021
- 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
- 9. Name and designation of officers :  
From the building side : Sh. Gaurav Tyagi (Chairman)
- 10. Year of Construction : 2012-2013
- 11. Applicant's letter No. : Nil dated 18/08/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 4.5 m NA	5.1 mtrs 3.4 mtrs. NA	M/R Being old case M/R Being old case NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	N/A	N/A	Ground Floor Only
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	N/A	N/A	Ground Floor Only
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	Ground Floor Only
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 M	.90 M (few single doors)	M/R being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A	N/A	N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	07 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	M/R M/R M/R







16.	<b>Provision of Lifts.</b>			<b>(No Lift)</b>
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/School/2018/SZ/2118 dated 25/09/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*R. K. Yadav*

Signature of Inspecting Officer

Name:- R.K. Yadav

Designation:- Asstt. Divisional Officer

8/9/2021

Divisional Officer (South West)

*09/09/2021*

*By CFO/152*

*F.T.*

*[Signature]*

*AO/152*

*F.T. letter is but up for review please*