



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2021/ 444

Dated:-14/09/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M/S Pragati Filling Station, at Jawahar lal Nehru Marg, New Delhi** comprised of Ground + 01 upper floor, Ground floor – ATM room, Workshop Manager's Office, Spare Parts Room, Electrical Panel Room, Toilets and First floor – Offices, Toilet, Spare Parts room was granted NOC by this department vide letter No.F6/DFS/MS/NDZ/2018/1503 dated 28/06/2018. The premises was re-inspected by the officer concerned of this department on **06/09/21** in the presence of Sh. Shailesh Jain (Partner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous Group J for petrol pump only** with effect from **14/09/2021**..... for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **14/09/2021**.....at New Delhi by.

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. M/S Pragati Filling Station,  
Jawahar lal Nehru Marg, New Delhi

**Condition for the validity of fire safety certificate**

1. This FSC is only for Petrol Pump.
2. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
3. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
4. 04 no's of co2 gas type ISI capacity of 4.5 kg. 02 no's of ABC stored pressure power type ISI capacity 05 kg and 01 numbers of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
5. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
6. Overhead electric cable shall not passed across the licensed premises.
7. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

2/7

INSPECTION REPORT

- 1. Name & address of the building M/S Pragati Filling Station, , Jawahar Lal Nehru Marg, New Delhi
- 2. Type of occupancy:- Hazardous Group J  
Ground + 01 upper floor
- 3. Type of case:- Renewal
- 4. Details of previous NOC:- No. F6/DFS/MS/NDZ/2018/1503 dated 28/06/2018
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 06/09/21
- 7. Name of the inspecting officer:- Sh. Ravinder Singh(ADO/CC)
- 8. Name & designation of officer  
From the building side:- Sh. Shailesh Jain (Partner)
- 9. Year of construction:- 2010
- 10. Applicant's letter No:- e-mail < pragatihyundai@hotmail.com> dated 25.08.21.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06 mtr.	30 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	0.80 mtr.	1 mtr.	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>E. Width of corridor</b>	N/A	N/A	N/A
	<b>F. Door size</b>	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	01 Nos mechanical foam 50 Kg, 01 Nos ABC 25 kg, 15 Nos ABC 4.5 Kg	01 Nos. mechanical foam 50 Kg, 01 Nos ABC 25 kg, 15 Nos ABC 4.5 Kg	MR
	2) Types	ABC, CO <sub>2</sub> , mech. foam trolley	ABC, CO <sub>2</sub> , mech. foam trolley	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			



	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	<b>No Smoking Signage English &amp; Hindi</b>	Required	Provided English & Hindi	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A

N/A  
N/A  
N/A

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckets with sand.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Further, The CNG pump is also operating in the same premises but no fire safety certificate is issued for CNG pump.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/NDZ/2018/1503 dated 28/06/2018, under rule 35 of the Delhi Fire Service Rules 2010. Accordingly, DFA is prepared and put up for kind perusal/approval and signature please.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
Name: - Ravinder Singh  
Designation: - ADO (CC)

DO (CD)

*[Handwritten Signature]*

8/9/21

*[Handwritten Signature]*

F.A. pl.

*[Handwritten Signature]*  
8/9/21



ADO (CC)

As approved, DFA is put up for kind perusal and signature pl.

*[Handwritten Signature]*

*[Handwritten Signature]*

*[Handwritten Signature]*  
8/9/21