

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 748

Dated: 15/9 / 2021

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya Bal Vidyalaya, Fatehpur Beri, New Delhi-110074 (ID 1923014) comprised of 1st Block, ground plus One upper floors & 2nd Block, ground plus three upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/771 Dt. 20/04/2018. The said premises was re-inspected by officer concerned of this department on 09/09/2021 in the presence of Dr. Rajveer (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and the new school block in accordance with rule 33 of Delhi Fire Service Rules, 2010, and that the building is fit for occupancy class "Educational Building Group – B" with effect from 15/9 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 15/9 2021 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The Principal, Sarvodaya Bal Vidyalaya, Fatehpur Beri, New Delhi-110074 (ID 1923014)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

NH0

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Bal Vidyalaya, Fatehpur Beri, New Delhi-110074 (ID -1923014)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Old Block - Ground plus one upper floor New Block- Ground + Three Upper Floor (01 Block)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/771 Dt. 20/04/2018		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	09/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Dr. Rajveer (Principal)		
10	Year of construction	Old bldg- 1979 & New Bldg. - 2016		
11	Applicant letter No.	Outdoor diary 2088 Dated 11/08/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE / UBBL Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	6 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Old block- 02 No's New Block - 04No's	Old block - 02 No's New Block - 04 No's	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 m / 0.75 m 1.50 mtr	Old bloc - 1.90 x 2 Nos & 1.40 m x 1 New Block - 1.80 m x 4 No's	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	New block - 2 No's	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	52 Nos	MR
	• Types	ABC / co2	26 ABC & 26 co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			

2/12

18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/771 Dt. 20/04/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

M
9/9/2021

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Design: ADO (BCP)

~~DO (SD)~~

Kirp
10/09/21

Dfo(S2)

[Signature]

F.T.

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature Pl

[Signature]
14/9/2021

Dh Lfo/S2