

C-59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 744

Dated: 14/9/21


FIRE SAFETY CERTIFICATE

Certified that St. Lawrence Convent Sr. Secondary School (under Gagan Educational Society) at Geeta Colony Facility Centre, Delhi-110031, comprised of ground plus three upper floors owned/occupied by M/s Gagan Educational Society was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1374 dated 13/06/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 23/08/2021 in the presence of Sh. Pankaj Jain, Manager of the school and that the school building is fit for occupancy class "B" 'Educational Building' with effect from 14/9/21 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on14/9/21..... at New Delhi by


13/9/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

O/C 

To,
The Principal,
St. Lawrence Convent Sr. Secondary School,
M/s Gagan Educational Society,
Geeta Colony Facility Centre,
Delhi-110031

Copy to:-
The Joint Director of Education,
Directorate of Education, Lucknow Road,
Delhi-110054

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

- | | |
|--|---|
| 1. Name & address of the building | : St. Lawrence Convent Sr. Secondary School,
(for M/s Gagan Educational Society) Geeta
Colony Facility Centre, Delhi-110031 |
| 2. Building is comprised of | : Ground plus three upper floors |
| 3. Type of Occupancy | : Educational |
| 4. Type of Case | : Renewal |
| 5. Details of Previous NOC letter | : F.6/DFS/MS/School/2018/NDZ/1374
dated 13/06/2018 |
| 6. Fire Safety direction letter No. | : Delhi Fire Service Act, 2007 and Rules 2010. |
| 7. Date of Inspection | : 23/08/2021 |
| 8. Name of the Inspecting officers | : ADO Nagender Singh |
| 9. Name and designation of Officer
from the building side | : Sh. Pankaj Jain, Manager |
| 10. Year of Construction | : 2000 |
| 11. Applicant's email ID | : helpdesk@stlawrenceconvent.com
dt- 28/07/2021 |

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 6 m 4.5 m N/A 	<ul style="list-style-type: none"> 15 m 6 m N/A 	<ul style="list-style-type: none"> MR MR N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 4 nos. N/A 	<ul style="list-style-type: none"> 4 nos. N/A. 	<ul style="list-style-type: none"> MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 1.5 m N/A 	<ul style="list-style-type: none"> 1.7 m, 1.7 m, 1.1 m & 1 m N/A 	<ul style="list-style-type: none"> MR(Accepted earlier) N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	d. No. of Continuous Staircases to Terrace	2 nos.	2 nos.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 30 nos. ABC /CO₂ ISI marked 	<ul style="list-style-type: none"> 30 nos. ABC /CO₂ ISI marked 	<ul style="list-style-type: none"> MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	4 nos.	4 nos.	MR
	• Length of hose reel hose	30m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	Provided	MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM X 2	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	30,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

N/19

17	Standby Power Supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew FSC under rule 37 of Delhi Fire Service Rules, 2010.

(Signature)
 (Nagender Singh)
 ADO (Shandara)

F.A. PI.

Dy. CFO (NDZ)

(Signature)
 21/9/21



(Signature)
 ADO (Shandara)

FT letter is placed for signatures please

(Signature)
 10/9/21

Dy. CFO (NDZ)

(Signature)
 13/9/21

T.A.S.CC11