

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 741

Dated: 14/9/2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Senior Sec. School, (ID-1309023)** Located at **Shalimar Village, Delhi-110088** comprised of **Ground + 01 Upper Floor** was issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2011/3330 Dated 02.12.2021. The said premise was re-inspected by the officer concerned of this department on 25.08.2021 in the presence of Ms. Neetu Ruhela (HOS) & Sh. Hukum Singh (Estate Manager) and found that the Management has added **06 Classrooms at Ground & 06 Classrooms at First Floor & has merged with old building** and have complied with the fire prevention and fire safety requirements in accordance **D.O.E., GNCT of Delhi Circular no.3298-3398 dated 01-03-2011** and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 14/9/21 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 14/9/21..... at New Delhi by.


 (Atul Garg)
 Director

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Girls Senior Sec. School, (ID-13009023) Located at Shalimar Village, Delhi-110088.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name and address of the building:- **Govt. Girls Sr Sec. School (ID-1309023)** Located at **Shalimar Village, delhi-110088.**
2. Type of Occupancy : Educational
3. Type of Case : Renewal/addition
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2011/3330 Date 02.12.2011
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 25.08.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Dr. Neetu Ruhela (HOS) & Sh. Hukum Singh (Estate Manager)
9. Year of Construction : 2011, 2012-13
10. Applicant's letter No. :email dated 18.08.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 02.12.2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	9 m	MR
	• Gate width	6 m	Direct accessible form road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	05 Nos.	MR
		NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtrs. If less than 1.5 additional .75 m is required	1.5, 1.43, 1.42, 1.34 & 1.30 mtrs.	MR
	• Upper floors			
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	100 cms	110 cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	• Total numbers	5 nos.	20 Nos. Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire Ext. provided near electrical panel	MR

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcoming vide letter no. F6/DFS/MS/School/2015/262 dated 05.02.2015 found rectified.

Note:- 12 new class rooms constructed in 2012-13 are merged with old building as per PWD letter no. AE/13/11 dated 03.02.2020. A new block is under construction & will be applied for NOC separately after completion of construction.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, issuance of Fire Safety Certificate issued is recommended.

S.P. Bhardwaj
ADO (WP)



CFO

~~*D/West*~~

6/9/2021

~~*DFS (W2)*~~

7/9/2021

7/9/21

~~*7/9/2021*~~

~~*D/West*~~