

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/School/WZ/2021/ 749

Dated: 15/9 /2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C. Primary School**, Located at **Haryana Power House Colony, Rohtak Road, Delhi-110035**, comprised of Ground Floor only was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2017/WZ/309 dated 03.03.2017. The said premises was re-inspected by the officer concerned of this department on 03.09.2021 in the presence of Ms. Pratibha Awasthi (Incharge) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 15/9/21 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 15/9/21 at New Delhi by.

DL (Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, M.C. Primary School, Haryana Power House Colony, Rohtak Road, Delhi-110035.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name & address of the building: **M. C. Primary School** Located at **Haryana Power House Colony, Rohtak Road, Delhi-110035**
2. Type of Occupancy : Educational (Ground Floor Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/309 dated 03.03.2017
5. Fire Safety directives Letter No. : Cr.No.3298-3398 dated-01-03-11
6. Date of inspection : 03.09.2021
7. Name of the Inspecting Officer : S. P. Bhardwaj, ADO (WP)
8. Name and designation of Officer  
from the building side : Ms. Pratibha Awasthi (Incharge)
9. Year of Construction : 1966
10. Applicant's letter No. : email dated 13.08.2021

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 1-3-11/ letter dated 13.03.2017 | Provided at site | Remarks MR/NMR |
|------|---|---|------------------|----------------|
| 1.   | Access of building  |   |                  |                |
|      | • Road width  | Accessible  | 9 m              | MR             |
|      | • Gate width  | Accessible  | Open Ground      | MR             |
|      | • Width of internal road                                    | NA  | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |   |                  |                |
|      | a. Number of staircases                                     |   |                  |                |
|      | • Upper floors  | NA  | NA               | NA             |
|      | • Basements   | NA  | NA               | NA             |
|      | b. Width of staircases                                      |   |                  |                |
|      | • Upper floors  | NA  | NA               | NA             |
|      | • Basements   | NA  | NA               | NA             |
|      | c. Protection of exits                                      |   |                  |                |
|      | • Fire check door   | NA  | NA               | NA             |
|      | • Pressurization  | NA  | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | NA  | NA               | NA             |
|      | e. Width Of Corridor  | NA  | NA               | NA             |
|      | f. Door Size  | 1m  | Provided         | MR             |
| 3.   | Compartmentation  |   |                  |                |
|      | • Fire check door   | NA  | NA               | NA             |
|      | • Sealing of electrical shafts                              | NA  | NA               | NA             |
|      | • Fire Rating of shaft door                                 | NA  | NA               | NA             |
|      | • Water Curtain   | NA  | NA               | NA             |
|      | • Fire Dampers  | NA  | NA               | NA             |
| 4.   | Smoke managements System                                    |   |                  |                |
|      | • Basements   | NA  | NA               | NA             |
|      | • Upper floors  | NA  | NA               | NA             |
| 5.   | Fire Extinguishers  |   |                  |                |
|      | • Total numbers   | 05 nos.   | Provided         | MR             |
|      | • Types   | ABC & CO <sub>2</sub>                                 | Provided         | MR             |
|      | • IS marking  | ISI marked  | Provided         | MR             |
| 6.   | First – Aid Hose Reels                                      |   |                  |                |
|      | • Total numbers on each floor                               | NA  | NA               | NA             |
|      | • Length of hose reel hose                                  | NA  | NA               | NA             |
|      | • Nozzle diameter   | NA  | NA               | NA             |



|     |  |    |    |    |
|-----|--|----|----|----|
| 7.  | Automatic fire detection and alarming system |    |    |    |
|     | • Type of detectors                          | NA | NA | NA |
|     | • Location of Main Panel                     | NA | NA | NA |
|     | • Location of Repeater Panel                 | NA | NA | NA |
|     | • Alternate source of power                  | NA | NA | NA |
|     | • Hooters' Location                          | NA | NA | NA |
| 8.  | MOEFA  | NA | NA | NA |
| 9.  | Public Address System                        | NA | NA | NA |
| 10. | Automatic Sprinkler System                   |    |    |    |
|     | • Basements                                  | NA | NA | NA |
|     | • Upper Floor                                | NA | NA | NA |
|     | • Sprinkler above false ceiling              | NA | NA | NA |
| 11. | Internal Hydrants:                           |    |    |    |
|     | • Size of riser/down-comer                   | NA | NA | NA |
|     | • Number of hydrants per floor               | NA | NA | NA |
|     | • Hose Box                                   | NA | NA | NA |
| 12. | Yard Hydrants                                |    |    |    |
|     | • Total number of hydrants                   | NA | NA | NA |
|     | • Hose Box                                   | NA | NA | NA |
| 13. | Pumping Arrangements:                        |    |    |    |
|     | • Ground Level                               |    |    |    |
|     | • Discharge of main pump                     | NA | NA | NA |
|     | ➤ Head of main pump                          | NA | NA | NA |
|     | ➤ Number of main pumps                       | NA | NA | NA |
|     | ➤ Jockey pump out put                        | NA | NA | NA |
|     | ➤ Jockey pump head                           | NA | NA | NA |
|     | ➤ Standby Pump out put                       | NA | NA | NA |
|     | ➤ Standby Pump Head                          | NA | NA | NA |
|     | ➤ Auto Staring/Manual stopping               | NA | NA | NA |
|     | ➤ Pump House Access                          | NA | NA | NA |
|     | • Terrace level                              |    |    |    |
|     | ➤ Discharge of pump                          | NA | NA | NA |
|     | ➤ Head of the pump                           | NA | NA | NA |
|     | ➤ Power supply                               | NA | NA | NA |
|     | ➤ Auto starting of pump                      | NA | NA | NA |
| 14. | Captive water Storage for firefighting:      |    |    |    |
|     | • Underground tank capacity                  | NA | NA | NA |
|     | ➤ Draw off connection                        | NA | NA | NA |
|     | ➤ Fire service inlet                         | NA | NA | NA |
|     | ➤ Access to tank                             | NA | NA | NA |
|     | • Overhead Tank capacity                     | NA | NA | NA |
| 15  | Exit Signage                                 | NA | NA | NA |
| 16. | Provision of Lifts                           |    |    |    |
|     | ➤ Pressurization of Lift Shaft               | NA | NA | NA |
|     | ➤ Pressurization of lift lobby               | NA | NA | NA |
|     | ➤ Communication in lift Car                  | NA | NA | NA |
|     | ➤ Fireman's Grounding Switch                 | NA | NA | NA |
|     | ➤ Lift Signage                               | NA | NA | NA |
| 17. | Standby power supply                         | NA | NA | NA |
| 18. | Refuge Area                                  |    |    |    |
|     | ➤ Total area                                 | NA | NA | NA |
|     | ➤ Location                                   | NA | NA | NA |
| 19. | Fire control room                            |    |    |    |
|     | ➤ Detector system panel                      | NA | NA | NA |
|     | ➤ Flow Switch Panel                          | NA | NA | NA |
|     | ➤ PA System Panel                            | NA | NA | NA |
|     | ➤ Battery backup                             | NA | NA | NA |
|     | ➤ Building Floor Plans                       | NA | NA | NA |

|     |  |    |    |    |
|-----|--|----|----|----|
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|-----|--|----|----|----|

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E circular no. 3298-3398 dated 1-3-11, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2017/WZ/309 dated 03.03.2017 is recommended.

*S.P. Bhardwaj*  
S.P. Bhardwaj, ADO (WP)

DO WEST/221  
DATE: 06/09/21

DO/west

dy  
6/9/21

Defo (WZ)

*[Signature]*  
7/9/21

ADO/w/p

FT is put up for signature.

Defo/wz

*[Signature]*  
15/9/21

*[Signature]*  
13/9/21

ms/ell