

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F6/DFS/MS/School/2021/ 752

Dated: 15/9/2021

FIRE SAFETY CERTIFICATE

Certified that the **North M.C Primary School** located at **E-block, Kamla Nagar, Delhi-110007** comprised of **Ground floor only** owned/occupied by **North M.C Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/SCHOOL/2017/WZ/149** dated **03.02.2017**. The premises was re-inspected by the officer concerned of this department on **09.09.2021** in presence of **Smt. Anupama Gupta (Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from **15.9.21**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **15.9.21**..... at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-25156707

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, North M.C Primary School located at E-block, Kamla Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : North M.C Primary School, E-block, Kamla Nagar, Delhi-110007.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground floor only)
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/149 Dated: 03.02.2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 09.09.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt. Anupama Gupta (Principal)
9. Year of Construction : 1962
10. Applicant's letter No. : Online E-mail dated: 27.08.2021

Plot Area-1000 sqm Covered Area:840 sqm No of class rooms -08 nos. No of students---135nos.


	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1 m	1.06m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	02nos	04nos	MR
	• Types	ABC/Co2	ABC-04	MR
	• ISI marking	ISI Marked	Provided	


15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular , the FSC issued vide letter of even no.149 dated 03.02.2017 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended


DO (F/W)
 Meena
 10/09/2021
 Dy CPO (WZ)



 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN


 10/9/2021

~~ADO/RN~~
 Dy CPO (WZ)

As approved, F.T. letter is put up for your signature please.


 15/9/2021


 14/09/2021