

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/ 754

Dated:- 16 /09/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya located at Gazipur, Delhi -110096 comprised of **Ground floor + 03 upper floor** owned/occupied by Sarvodaya Kanya Vidyalaya. The premises was inspected by the officer concerned of this department on 07/09/2021 in the presence of Mr. Deepak JE (E) & Mr. Ashok Kumar (Estate Manage) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "B" 'Educational Building' **Ground + 03 upper floors** with effect from 16/9/21..... for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 16/9/21..... at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,  
D-Block, Yamuna Vihar, Delhi-110053.
2. The Principal,  
Sarvodaya Kanya Vidyalaya,  
Gazipur, Delhi -110096. School ID no. 1002184.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

2/16

**INSPECTION REPORT**

1. Name & address of the building:- **Sarvodaya Kanya Vidyalaya at Gazipur, Delhi -110096**
2. Type of occupancy:- Educational Group, Gr. + 03 upper floors
3. Type of case:- New Case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- DFS Act 2007 and Rule 2010
6. Date of inspection:- 07/09/2021
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer  
From the building side:- Mr. Deepak JE (E) & Mr. Ashok Kumar (Estate Manager)
9. Year of construction:- 2001
10. Applicant's letter No:- SKV/GZP/2021/898 dated 10/08/2021.

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement | Provided at site | Remarks<br>MR/NMR |
|-------|---|-------------|------------------|-------------------|
| 1.    | Access to Building  |             |                  |                   |
|       | 1) Road width   | 06 mtr.     | 06 mtr.          | MR                |
|       | 2) Gate width   | 4.5 mtr.    | 4.5 mtr.         | MR                |
|       | 3) Width of internal road                                   | NA          | NA               | NA                |
| 2.    | Number, Width Type & Arrangement of Exits                   |             |                  |                   |
|       | A. Number of staircases                                     |             |                  |                   |
|       | 1. Upper floors   | 02 Nos.     | 03 nos.          | MR                |
|       | 2. Basements  | N/A         | N/A              | N/A               |
|       | B. Width of staircase                                       |             |                  |                   |
|       | 1. Upper floors   | 1.5 m       | 1.5 m each       | MR                |
|       | 2. Basements  | N/A         | N/A              | N/A               |
|       | C. Protection of exits                                      |             |                  |                   |
|       | 1. Fire check door  | N/A         | N/A              | N/A               |
|       | 2. Pressurization   | N/A         | N/A              | N/A               |
|       | D. No. of continuous staircase to terrace                   | 02 nos.     | 02 nos.          | MR                |
|       | E. Width of corridor  | 1.5 mtr     | 1.8 mtr          | MR                |
|       | F. Door size  | 1.0 mtr.    | 1.2 mtr.         | MR                |
| 3.    | Compartmentation  |             |                  |                   |
|       | 1) Fire check door  | N/A         | N/A              | N/A               |
|       | 2) Sealing of electrical shafts                             | N/A         | N/A              | N/A               |
|       | 3) Fire rating of shaft door                                | N/A         | N/A              | N/A               |
|       | 4) Water curtain  | N/A         | N/A              | N/A               |
|       | 5) Fire Dampers   | N/A         | N/A              | N/A               |
| 4.    | Smoke Management System                                     |             |                  |                   |
|       | 1) Basements  | N/A         | N/A              | N/A               |
|       | 2) Upper floors   | N/A         | N/A              | N/A               |
| 5.    | Fire Extinguishers  |             |                  |                   |
|       | 1) Total numbers  | 27 Nos.     | 27 Nos.          | MR                |
|       | 2) Types  | ABC & CO2   | ABC, CO2         | MR                |
|       | 3) ISI marking  | Required    | Provided         | MR                |

N/17

|     |  |          |          |     |
|-----|--|----------|----------|-----|
| 6.  | First-Aid Hose Reel                        |          |          |     |
|     | 1) Total number of each floor              | 02 no.   | 02 no.   | MR  |
|     | 2) Length of hose reel hose                | 30 m     | 30 m     | MR  |
|     | 3) Nozzle diameter                         | 5 mm     | 5 mm     | MR  |
| 7.  | Automatic Fire Detection & Alarming System |          |          |     |
|     | 1) Type of detectors                       | N/A      | N/A      | N/A |
|     | 2) Location of main panel                  | N/A      | N/A      | N/A |
|     | 3) Location of repeater panel              | N/A      | N/A      | N/A |
|     | 4) Alternate source of power               | N/A      | N/A      | N/A |
|     | 5) Hooter's Location                       | N/A      | N/A      | N/A |
| 8.  | MOEFA                                      | N/A      | N/A      | N/A |
| 9.  | Public Address System                      | N/A      | N/A      | N/A |
| 10. | Automatic Sprinkler System                 |          |          |     |
|     | 1) Basement                                | N/A      | N/A      | N/A |
|     | 2) Upper floors                            | N/A      | N/A      | N/A |
|     | 3) Sprinkler above false ceiling           | N/A      | N/A      | N/A |
| 11. | Internal Hydrants                          |          |          |     |
|     | 1) Size of riser/down-comer                | N/A      | N/A      | N/A |
|     | 2) Number of hydrants per floor            | N/A      | N/A      | N/A |
|     | 3) Hose box                                | N/A      | N/A      | N/A |
| 12. | Yard Hydrants                              |          |          |     |
|     | 1) Total number of hydrants                | N/A      | N/A      | N/A |
|     | 2) Hose box                                | N/A      | N/A      | N/A |
| 13. | Pumping Arrangement                        |          |          |     |
|     | 1) Ground level                            | N/A      | N/A      | N/A |
|     | a) Discharge of main pump                  | N/A      | N/A      | N/A |
|     | b) Head of main pump                       | N/A      | N/A      | N/A |
|     | c) Number of main pump                     | N/A      | N/A      | N/A |
|     | d) Jockey pump out put                     | N/A      | N/A      | N/A |
|     | e) Jockey pump head                        | N/A      | N/A      | N/A |
|     | f) Stand by pump output                    | N/A      | N/A      | N/A |
|     | g) Stand by pump head                      | N/A      | N/A      | N/A |
|     | h) Auto starting/Manual stopping           | N/A      | N/A      | N/A |
|     | 2) Terrace level                           |          |          |     |
|     | a) Discharge of pump                       | 450 LPM  | 450 LPM  | MR  |
|     | b) Head of pump                            | 40 m     | 40 m     | MR  |
|     | c) Power supply                            | Required | Provided | MR  |
|     | d) Auto starting of pump                   | Required | Provided | MR  |

|     |  |             |             |     |
|-----|--|-------------|-------------|-----|
| 14. | Captive Water Storage for Fire Fighting                                |             |             |     |
|     | 1) Under ground tank capacity  | N/A         | N/A         | N/A |
|     | a) Draw-off connection   | N/A         | N/A         | N/A |
|     | b) Fire service inlet  | N/A         | N/A         | N/A |
|     | c) Access to tank  | N/A         | N/A         | N/A |
|     | d) Over head tank capacity   | 10,000 ltr. | 10,000 ltr. | MR  |
| 15. | Exit Signage.  | Required    | Provided    | MR  |
| 16. | Provision of Lifts.  |             |             |     |
|     | a) Pressurization of lift shaft  | N/A         | N/A         | N/A |
|     | b) Pressurization of lift lobby  | N/A         | N/A         | N/A |
|     | c) Communication in lift car   | N/A         | N/A         | N/A |
|     | d) Fireman's switch  | N/A         | N/A         | N/A |
|     | e) Lift signage  | N/A         | N/A         | N/A |
| 17. | Stand by Power Supply  | N/A         | N/A         | N/A |
| 18. | Refuge Area  |             |             |     |
|     | Total area location  | N/A         | N/A         | N/A |
| 19. | Fire Control Room  |             |             |     |
|     | a) Detector system panel   | N/A         | N/A         | N/A |
|     | b) Flow switch panel   | N/A         | N/A         | N/A |
|     | c) PA system panel   | N/A         | N/A         | N/A |
|     | d) Battery backup  | N/A         | N/A         | N/A |
|     | e) Building floor plan   | N/A         | N/A         | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: |             |             | N/A |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/ 2021/NDZ/307 dated 23/06/2021 have been rectified.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

*M.K. Sharma*  
5/9/21

Name :- M.K. Sharma  
Designation :- ADO (LN)

Dy. CEO/NDZ

*K. D. Singh*  
8/5/21

CFO(NDZ) - D/NDZ

Director / *A. K. Singh*  
13/09/2021