

C-22

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 762

Dated: 21/09/2021

FIRE SAFETY CERTIFICATE

Certified that the building Gyan Sagar public school Located at Raj Nagar – II, Palam colony, New Delhi - 11007, comprised of Ground + 3 Upper floors was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1145 Dated-18/05/2018. The premises was re inspected by the officers concerned of this department on 11/09/2021 in the presence of Ms.Meena kumari (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 – 263 dated 17/01/2005 and that the premises is fit for occupancy class B “Educational building” with effect from 21/9/21 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/9/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Ms.Meena kumari (Principal) Gyan Sagar public school Located at Raj Nagar – II, Palam colony, New Delhi – 11007.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

119
INSPECTION REPORT

3. Name & address of the building: Gyan Sagar public school Located at Raj Nagar – II, Palam colony, New Delhi - 11007
4. Type of Occupancy : Educational (G+ 03 Upper Floors)
5. Type of Case : Renewal
6. Details of previous NOC : F6/DFS/MS/School/2018/SZ/145 Dated- 18/05/2018
7. Fire Safety directives Letter No. : DOE Circular No. 262-263 Dated 17/01/2005
8. Date of inspection : 11-09-2021
9. Name of the Inspecting Officer : Udai vir Singh, ADO (DWK)
10. Name and designation of Officer
from the building side : Ms.Meena kumari (Principal)
11. Year of Construction : 2009
12. Applicant's letter No. : Email Dated 02/09/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6	Provided at site	Remarks MR/NMR																																															
1.	Access of building																																																		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>Accessible</td> <td>Provided</td> <td>Old Case</td> </tr> <tr> <td>4.5mtrs</td> <td>Directly accessible from road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible	Provided	Old Case	4.5mtrs	Directly accessible from road	MR	NA	NA	NA																																								
Accessible	Provided	Old Case																																																	
4.5mtrs	Directly accessible from road	MR																																																	
NA	NA	NA																																																	
2.	Number, width, Type & Arrangements of exits																																																		
	<table border="1"> <tr> <td>a. Number of staircases</td> <td></td> <td></td> <td></td> </tr> <tr> <td>• Upper floors</td> <td>02 Nos.</td> <td>02 Nos.</td> <td>MR</td> </tr> <tr> <td>• Basements</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>b. Width of staircases</td> <td></td> <td></td> <td></td> </tr> <tr> <td>• Upper floors</td> <td>1.70m, 1.40 m</td> <td>Old case</td> <td>Old case</td> </tr> <tr> <td>• Basements</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>c. Protection of exits</td> <td></td> <td></td> <td></td> </tr> <tr> <td>• Fire check door</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>• Pressurization</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>d. No of continuous staircase to terrace</td> <td>01 Nos.</td> <td>01</td> <td>MR</td> </tr> <tr> <td>e. Width Of Corridor</td> <td>1.5 mtr</td> <td>175cm</td> <td>MR(Old case)</td> </tr> <tr> <td>f. Door Size</td> <td>1 mtr</td> <td>96cm (including door frame)</td> <td>MR(Old case)</td> </tr> </table>	a. Number of staircases				• Upper floors	02 Nos.	02 Nos.	MR	• Basements	NA	NA	NA	b. Width of staircases				• Upper floors	1.70m, 1.40 m	Old case	Old case	• Basements	NA	NA	NA	c. Protection of exits				• Fire check door	NA	NA	NA	• Pressurization	NA	NA	NA	d. No of continuous staircase to terrace	01 Nos.	01	MR	e. Width Of Corridor	1.5 mtr	175cm	MR(Old case)	f. Door Size	1 mtr	96cm (including door frame)	MR(Old case)		
a. Number of staircases																																																			
• Upper floors	02 Nos.	02 Nos.	MR																																																
• Basements	NA	NA	NA																																																
b. Width of staircases																																																			
• Upper floors	1.70m, 1.40 m	Old case	Old case																																																
• Basements	NA	NA	NA																																																
c. Protection of exits																																																			
• Fire check door	NA	NA	NA																																																
• Pressurization	NA	NA	NA																																																
d. No of continuous staircase to terrace	01 Nos.	01	MR																																																
e. Width Of Corridor	1.5 mtr	175cm	MR(Old case)																																																
f. Door Size	1 mtr	96cm (including door frame)	MR(Old case)																																																
3.	Compartmentation																																																		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1"> <tr> <td>Required</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Required	Provided	MR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA																																		
Required	Provided	MR																																																	
NA	NA	NA																																																	
NA	NA	NA																																																	
NA	NA	NA																																																	
NA	NA	NA																																																	

14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/145 Dated-18/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *ASD/OWR*

ASD/OWR

15/09/2021
by cfo. (52)

F.T.