

C-18

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 761

Dated: 21/09/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Building S.D.M.C Primary School Located at Sarangpur, New Delhi – 110073 comprised of Ground Floor only, having 02 rooms (Including class room & Office) was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2018/SZ/899 Dated 03/05/2018. The premises was re inspected by the officer concerned of this department on 14/09/2021 in the presence of Sh. Bhupender kumar (Incharge). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class “Educational” with effect from the date of issue of this certificate for a period of three years, subject to compliance of the condition given below.

Issued on 21/9/21 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. The Principal, S.D.M.C Primary School, Sarangpur, New Delhi – 73 (School ID-1757193)
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: S.D.M.C Primary School Located at Sarangpur, New Delhi – 110073.
2. Type of Occupancy : Educational ( 01 Blocks=Ground Floor Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/899Dated 03/05/18
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 14/09/2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer

from the building side: Mr. Bhupender Kumar (Incharge)

9. Year of Construction : 2010
10. Applicant's letter No. :Email dated 25/08/2021

No. of Students=31  
 No. of class rooms=02  
 Plot area=7056 sq.yard  
 Covered area=600 sq.yard

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/5	Provided at site	Remarks MR/NMR																								
1.	<b>Access of building</b>																											
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Accessible 06 mtr</td> <td>06 mtr</td> <td>MR</td> </tr> <tr> <td>4.5 mtr</td> <td>Directly accessible from road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible 06 mtr	06 mtr	MR	4.5 mtr	Directly accessible from road	MR	NA	NA	NA																	
Accessible 06 mtr	06 mtr	MR																										
4.5 mtr	Directly accessible from road	MR																										
NA	NA	NA																										
2.	<b>Number, width, Type &amp; Arrangements of exits</b>																											
	<ul style="list-style-type: none"> <li>a. Number of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>b. Width of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>c. Protection of exits</li> <li>• Fire check door</li> <li>• Pressurization</li> <li>d. No of continuous staircase to terrace</li> <li>e. Width Of Corridor</li> <li>f. Door Size</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>NA</td> <td>NA</td> <td>Ground floor only</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>Ground floor only</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>01m</td> <td>01 m (Including door frame)</td> <td>MR(Old Case)</td> </tr> </table>	NA	NA	Ground floor only	NA	NA	NA	NA	NA	Ground floor only	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	01m	01 m (Including door frame)	MR(Old Case)		
NA	NA	Ground floor only																										
NA	NA	NA																										
NA	NA	Ground floor only																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
01m	01 m (Including door frame)	MR(Old Case)																										
3.	<b>Compartmentation</b>																											
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA											
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										



4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	02 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC & CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Staring/Manual stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>			
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>			



N/11

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/899 Dated 03/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *HO/Secy*

*DO/Secy*

*15/09/2021*

*By chd (2)*

*15/9*

*F.t.*