

G-17

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 766

Dated: 22/09/2021

FIRE SAFETY CERTIFICATE

Certified that the Vidya Bhawan Mahavidyalaya Sr. Sec. School located at Lodhi Estate, New Delhi-110003 comprised of three blocks, Front Block - Ground & One Upper Floor & Two Rear Blocks – Ground & Two Upper Floors only owned / occupied by Vidya Bhawan Mahavidyalaya School was issued Fire Safety Certificate by this department Vide letter No. F6/DFS/MS/School/2018/SZ/330 dated 27/02/2018. The premises was re-inspected by the officer concerned of this department on 13/09/2021 in the presence of Dr. Ashok Kumar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 22/09/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 22/09/2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. Principal, Vidya Bhawan Mahavidyalaya Sr. Sec. School, Lodhi Estate, New Delhi-110003.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Vidya Bhawan Mahavidyalaya Sr. Sec. School,
Lodhi Estate, New Delhi-110003.
2. Type of Occupancy : Educational
3. Building Comprised of : Front Block - Ground + One Upper Floor
Two Rear Blocks – Ground + Two Upper Floors
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2018/SZ/330 dated 27/02/2018
6. Fire Safety directives Letter No. : DOE Cir. Dated 17/01/2005
7. Date of inspection : 13/09/2021
8. Name of the Inspecting Officer : A.D.O. (S.J.)
9. Name and designation of Officer
from the building side : Dr. Ashok Kumar (Principal)
10. Year of Construction : 1956
11. Applicant's letter received through email ID-vidya_bgawab1959@rediffmail.com dated 10/08/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC / BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	18 m	MR
	• Gate width	Required	2 gate width 4 mtr & 4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	Required	1.35m & 1.48m	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	Required	1	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	Required	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	Required	16	MR
	• Types	ABC /Co ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

	• Total numbers on each floor	1	5	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	Required	450 LPM	MR
	➤ Head of the pump	Required	35 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	D.G. Set	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

General requirements for schools as per DOE Cir. Dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/SZ/330 dated 27/02/2018 renewal under rule 35 of the Delhi Fire Service rules 2010.

Ashok Kumar Jaiswal
14/9/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

DO(SD)

14/09/21

DeFO(SJ)

14/09/21

F.T.