

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Hospital/2021/NDZ/ 457

Dated: 21/09/2021

FIRE SAFETY CERTIFICATE

Certified that the Vivekanand Pratishthan Parishad, Vivekanand Hospital Yogashram at Patparganj Road, Khureji, Delhi-110051, comprised of basement, ground plus three upper floors owned/occupied Vivekanand Pratishthan Parishad was issued FSC vide letter No.F.6/DFS/MS/Hospital/2018/2289 dated 10/10/2018. The hospital building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 31/08/2021 in the presence of Acharya Dr. Vikrmaditya founder of the hospital and that the building is fit for occupancy class "C" 'Institutional Building' with effect from 21/09/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on 21/09/2021 at New Delhi by


21/9/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

Acharya Dr. Vikrmaditya,
Vivekanand Pratishthan Parishad,
Vivekanand Hospital Yogashram,
Patparganj Road, Khureji, Delhi-110051

Copy:-

The Directorate of Health Services,
M.O./C Nursing Home Cell,
Govt. of NCT of Delhi,
F-17, Karkardooma, Delhi-110032

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Vivekanand Pratishtan Parishad,
Vivekanand Hospital Yogashram, Patparganj
Road, Khureji, Delhi-110051
2. Building is comprised of : Basement, ground plus three upper floors
3. Type of Occupancy : Institutional
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/Hospital/2018/2289
dated-10/10/2018
6. Fire Safety direction letter No. : F.6/MS/DFS/Hospital/2001/328
dated 23/02/2001
7. Date of Inspection : 31/08/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer
from the building side : Acharya Dr. Vikrmaditya
10. Year of Construction : 2004
11. Applicant's email ID : vivekanandpratishtanparishad@gmail.com
dated 19/07/2021

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	6 m	30 m	MR
	• Gate width	N/A	3.5 m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	1 no.	1 no.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper floor	2 m	2 m	MR
	• Basement	2 m	2 m & 1.24 m	MR(accepted earlier)
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	1 no.	1 no.	MR
	e. Width of Corridor	2.4 m	2.4 m	MR
	f. Door Size	1 m	1 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust Provided	MR
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC/Co2	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat & Smoke	Smoke	MR
	• Location of main panel	Control room	Main Entrance	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	Staircases	Provided(each floor)	MR
08	MOEFA	Required	Provided(each floor)	MR
09	Public Address System.	Required	Provided(each floor)	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	1 no.	1 no.	MR
	• Hose box	1 no.	1 no.	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	450 LPM	450 LPM	MR
	• Head of main pump	40 m	40 m	MR
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,00,000 Ltrs.	1,00,000 Ltrs.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs.	25,000 Ltrs.	MR
15	• Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

Abhugh
 (Nagender Singh)
 ADO (Shahdara)

Dy. CFO (NDZ)

F.I. pl.

QKumar
 16/12/21

ADOCs/kan FT letter is placed for signatures please

Abhugh
 17/12

Dy. CFO (NDZ)

QKumar
 17/12/21

MSCCII

