

538

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F6/DFS/MS/School/2021/ **770**

Dated: **22/ 9 /2021**

FIRE SAFETY CERTIFICATE

Certified that the **Rosary Senior Se. Sec School** located at **Radio Colony Kingsway Camp, Delhi-110009** comprised of **02 blocks (Ground +03 upper floors & Ground +02 upper floors only)** owned/ occupied by **Rosary Senior Se. Sec School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2018/School/2207 dated 28.09.2018** The premise was re-inspected by the officer concerned of this department on **14.09.2021** in the presence of **Fr. Savariraj (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **22/9/21** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **22/9/21** at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-25104544

o/c

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Rosary Senior Se. Sec School at Radio Colony Kingsway Camp, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Rosary Senior Sec. School, Radio Colony, Kingsway Camp, Delhi-09.
2. Type of Occupancy : Educational
3. Type of Case : Renewal 02 blocks (G+03 upper floor & G+02 upper floor)
4. Details of previous NOC : No F6 / DFS /MS/2018/School/2207 dated 28.09.2018
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 14.09.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Fr. Savariraj (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : Online E-mail dated 09.09.2021

Plot Area-4.25 acre Covered Area:6000 sq.y, class rooms -59 nos students---1345 nos

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	12m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	A-Block- 1.60m &1.45m B-Block- 1.50,1.55m & 1.50m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 each block	Provided	MR
e. Width of Corridor	1.50m	2.50m	MR	
f. Door Size	1 m	1.10 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	25nos	26nos	MR
	• Types	ABC/Co2	ABC--26	MR
	• ISI marking	ISI Marked	Yes	MR

6	First-Aid Hose Reels.				
	• Total numbers on each floor	02each block	Provided	MR	
	• Length of hose reel hose	30m	30m	MR	
	• Nozzle diameter	5mm	5mm	MR	
7	Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8	MOEFA				
9	Public Address System.				
		NA	NA	NA	
10	Automatic Sprinkler System.				
	• Basement	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11	Internal Hydrants				
	• Size of riser/down-comer	100mm	100mm	MR	
	• Number of hydrants per floor	02 each block	Provided	MR	
	• Hose Box	02	02	MR	
12	Yard Hydrants.				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13	Pumping Arrangements.				
	• Ground Level	➤ Discharge of main Pump	N/A	N/A	N/A
		➤ Head of Main pump	N/A	N/A	N/A
		➤ Number of main pumps	N/A	N/A	N/A
		➤ Jockey Pump out put	N/A	N/A	N/A
		➤ Jockey pump head	N/A	N/A	N/A
		➤ Standby Pump out put	N/A	N/A	N/A
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
		➤ Pump House Access	N/A	N/A	N/A
		• Terrace level	➤ Discharge of pump	450lpm x 02	450lpm x 02
	➤ Head of the pump		40m	40m	MR
	➤ Power Supply		N/A	N/A	N/A
	➤ Auto Starting of pump		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.				
	• Underground tank capacity	40,000 ltr.	Provided	MR	
	➤ Draw-off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	NA	NA	NA	
	• Overhead Tank capacity	5,000 ltrs x02	Provided	MR	

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, the FSC issued vide letter of even no. 2207 dated 28.09.2018 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

~~DO (NW)~~

~~K~~
17/09/2021

~~Dy CFO (W2)~~

~~ADO/R IN~~

~~Dy CFO (W2)~~

As approved, F-i. letter is put up for your signature pl.

~~J~~
27/9/2021

16/09/2021
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

~~C.L.~~
21/09/2021