

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001

No. F6/DFS/MS/2021/247

Dated: 22/09/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Lalji Foods located at **Ground Floor & First Floor, A2/43, Rajouri Garden, New Delhi – 110027** in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by M/s Lalji Foods was issued Fire Safety Certificate Vide Letter No. F6/DFS/MS/2018/WZ/224 dated 08.02.2018. The premises was re-inspected by the officer concerned of this department on 31/08/2021 in the presence of Mr. Manoj Rajput (Manager - Accounts) and found that the said building have deemed complied with the fire prevention & Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 22/09/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 22/09/2021 at New Delhi by.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to:

1. Sh. Kishan Kumar Aggarwal,  
M/s Lalji Foods, Ground Floor & First Floor,  
A2/43, Rajouri Garden, New Delhi.
2. Dy. Health Officer, West Zone,  
SDMC, Public Health Department,  
Vishal Enclave, New Delhi.

o/c  
22/09/2021

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The restaurant management have submitted an undertaking that they will not use 2<sup>nd</sup> & 3<sup>rd</sup> Floor for restaurant purpose & it is used, the FSC will be null & void.

## INSPECTION REPORT

1. Name & address of the building: M/s Lalji Foods, Ground & First Floor, A2/43, Rajouri Garden, New Delhi.
2. Type of Occupancy : Assembly (Restaurant) (Basement + Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/WZ/224 dated 08-02-2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/2308 dated 24-09-2013
6. Date of inspection : 31.08.2021
7. Name of the Inspecting Officer : ADO (MN)
8. Name and designation of Officer From the building side : Sh. Manoj Rajput (Manager – Accounts)
9. Year of Construction : 2014
10. Applicant's letter No. : Online Application No:- 2021040211959 dated 02-04-2021

Basement – Storage, Ground & First Floor  
– Restaurant  
Second & Third Floor - Empty

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirements/As Per Pre. Insp. Rep. dtd. 30.01..2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>24 m</li> <li>5 m</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>On Main Road</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>3</li> <li>3</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	<ul style="list-style-type: none"> <li>2X1.5m &amp; 1X1m</li> <li>2X1.5m &amp; 1X1m</li> </ul>	<ul style="list-style-type: none"> <li>153 cm, 162cm &amp; 103 cm</li> <li>2X160cm, 103 cm &amp; 80 cm</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>Required</li> <li>Required</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> <li>•</li> </ul>	<ul style="list-style-type: none"> <li>3</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> </ul>
	e. Width Of Corridor			
	<ul style="list-style-type: none"> <li>•</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> </ul>
	f. Door Size			
	<ul style="list-style-type: none"> <li>•</li> </ul>	<ul style="list-style-type: none"> <li>2X2m</li> </ul>	<ul style="list-style-type: none"> <li>2X2m &amp; 145 cm</li> </ul>	<ul style="list-style-type: none"> <li>MR being old case</li> </ul>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>Required</li> <li>Required</li> <li>Required</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> <li>Provided</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> <li>NA</li> <li>NA</li> </ul>

	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	Provided	MR
5.	Fire Extinguishers	12 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	18 nos. ABC & CO <sub>2</sub> ISI marked	Provided	MR
6.	First - Aid Hose Reels		Provided	MR
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2 30 m 5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 2 2	Provided	MR
			Provided	MR
12.	Yard Hydrants		Provided	MR
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NR	NR	NR
		NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2280 lpm 60 m 1 180 lpm 60 m 2280 lpm 60 m Required Required 450 lpm 40 m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	50,000 liters Required Required Required 10,000 ltrs Required	Provided	MR
			Provided	MR
			Provided	MR
			Provided	MR
15	Exit Signage		Provided	MR
			Provided	MR


16.	Provision Of Lifts : <b>No lift is installed</b>			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	Required	Provided	MR
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
		NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no. : F6/DFS/MS/2018/WZ/224 dated 08/02/2018 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The restaurant management have submitted an undertaking that they will not use 2<sup>nd</sup> & 3<sup>rd</sup> floor for restaurant purpose & if it is used, the FSC will be null & void.

~~Do (upt)~~


  
15/09/2024

216  
16.09.21


  
16/9/2024

Signature of inspecting Officer  
Name: Sarabjeet Singh  
Designation:-A.D.O. (M.N.)

~~DCFO (W2)~~

  
17/9/2021

AAD/ M M Sir, F.T is put up for your perusal & Signature pls.

  
22/09/2024

~~DCFO (W2)~~