

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No. F6/DFS/MS/EH/WZ/2021 242

Dated: 22 / 9 / 2021

FIRE SAFETY CERTIFICATE

Certified that **M/s Bikanervala Foods Pvt. Ltd. Located at Plot No. 07 Ground Floor and First Floor Block 02 WHS Kirti Nagar, New Delhi - 110015** in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by **M/s M/s Bikanervala Foods Pvt Ltd** Fire Safety Certificate was already issued by this department vide letter no. F6/DFS/MS/2018/WZ/2402 dated 26/10/2018. The premises was re-inspected by the officer of this department on 06-09-2021 in the presence of Mr. Raman Deep Singh (Director) & observed that all the fire prevention and fire safety arrangements provided in the premises/building found in good working condition. The premises have deemed complied with Fire prevention and Fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 22/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed overleaf.

Issued on ... 22/9/21 ... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. M/s Bikanervala Foods Pvt Ltd. Located at Plot No. 07 Ground Floor and First Floor Block 02 WHS Kirti Nagar, New Delhi – 110015. (Ref. Online ID. No. 2021041212802 dated: - 31/07/2021)
2. Dy. Health Officer, West Zone, SDMC, Public Health Department, Vishal Enclave, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Bikanervala Foods Pvt Ltd. Plot No. 07 GF and FF Block 02 WHS Kirti Nagar, New Delhi - 110015**
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/WZ/2402 Dated 26/10/2018
5. Fire Safety directives Letter No. : As given at N/2
6. Date of inspection : 26/08/2021
7. Name of the Inspecting Officer : Sarabjeet Singh ADO(MN)
8. Name and designation of Officer from the building side : Sh. Mainsh Aggarwal (Manager)
9. Year of Construction : 2015 (As per previous inspection report)
10. Applicant's letter No. : Online application no 2021041212802 dated 31.07.2021

The said restaurant is running at Ground & First floor In a building comprised of Basement + Ground +3 upper Floors

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements/ As per Pre. Insp. Rep. dtd. 18.07.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	12 mts Provided	MR
	• Gate width	NA	On main Road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 x 1.5mts	153 cm, 150cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2	MR
	• Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1m	GF - 2m & 130cm FF - 1m	MR (being old case)

AS

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided in kitchen	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NR	Provided	NR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA

	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	25,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2018/WZ/2402 Dated 26/10/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO (west)

223/ADO/MN
27/08/2021

DO
28/8/2021

DO
27/8/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

DO (WEST) 196
DATED 28/08/2021
03/09/2021

DO (WZ) What about doors of 1st floor

DO
3/9

DO (WZ)

ADO (MN) Sir, 1st floor restaurant is