

c-31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/SCHOOL/2021/NDZI/ 722

Dated: 7/9/21

FIRE SAFETY CERTIFICATE

Certified that M/s Arwachin International School located at Pocket B, Facility Centre, Dilshad Garden, Delhi-110095, comprised of basement, ground plus three upper floors only, owned/occupied by Arwachin International School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1810 dated 03/08/18. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Harish Sharma, Admn. Officer of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for basement, Ground plus three upper floor occupancy class "B" 'Educational Building' with effect from 7/9/21 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....7/9/21.....at New Delhi by


7/9/21

**(Dr. S.K Tomar)
Chief Fire Officer**



To,
The Manager
Arwachin International School
Pocket B, Facility Centre, Dilshad Garden,
Delhi-110095

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Arwachin International School,
Pocket B, Facility Centre, Dilshad Garden, Delhi-95
2. Building is comprised of : Basement, ground plus three upper floors only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/1810 dt.03/08/18
6. Fire Safety directive letter No : F.6/DFS/MS/BP/2003/1003 dated 12/05/2003
7. Date of Inspection : 28/08/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Harish Sharma, Admin. Officer
10. Year of Construction : 2005
11. Applicant's letter No : Email, Dated- 17/06/2021

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV /Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	12 mtr.	12 mtr.	MR
	• Gate width	4.50 mtr	06 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	04 nos.	04 nos.	MR
	• Basement	02 nos	02 nos	MR
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 no.	03 no.	MR
	e. Width of Corridor	1.50 mtr.	02 mtr.	MR
	f. Door Size	01 mtr.	1.20 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Naturally ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	23 nos.	35 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	Provided	MR
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	MR
	• Hose Box	N/A	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	1650 lpm	1650 lpm	MR
	➤ Head of Main Pump	40 mtr	40 mtr	MR
	➤ Number of main pumps	01 no.	01 no.	MR
	➤ Jockey pump out put	180 lpm	180 lpm	MR
	➤ Jockey pump head	40 mtr	40 mtr	MR
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	450 Lpm.	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 ltr	50,000 ltr	MR
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 Ltr.	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renewal Fire Safety Certificate under the rule 35 of Delhi Fire Service rules 2010

Mehmood
11/9/2021

Signature of the Inspecting Officer
Name : Mehmood
Designation : ADO (Tahirpur)

Dy. CFO (NDZ)

F.S. pl.

Mehmood
11/9/21

ADO (T.B.) *li*

A G-3 bus up for regular inspection

ADO (NDZ)

Pl. put date on sign

Mehmood
11/9/21

ADO (T.B.)

Mehmood
11/9/2021

ADO (T.B.)