

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F.6/FDS/MS/CNG/SZ/2021/ 463

Dated: 24/9/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **CNG Filling Station at Narayana Depot, (Hybrid) (near DTC Depot gate for outside vehicle), Delhi- 110028**, comprised of **Ground Floor Only** owned/Occupied by Indraprastha Gas Limited. The Premises was inspected by officer concerned of this department on **07.09.2021** in presence of **Sh. Sanchit Sehrawat ( Dy. Manager)** and found that the premises have complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/premises fit for occupancy **CNG Filling Station Group "J"** with effect from **24/9/2021** for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on **24/9/2021** at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot No. 04, Community Center, R.K. Puram, Sec- 9, New Delhi- 110022.
2. The Joint Commissioner of Police (Lic.), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : CNG Filling Station, Narayana Depot (Hybrid), near DTC depot gate for outside vehicle), New Delhi- 110028
2. Type of Occupancy : Hazardous (Group- J)
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2019/7923 dated 31.12.2019
6. Date of inspection : 07.09.2021
7. Name of the Inspecting Officers : P.V Rathee, ADO (SRD)
8. Name and designation of officers from the building side : Sh. Sanchit Sehrawat, (Dy. Manager)
9. Year of Construction : 2019
10. Applicant's letter No. : Email ID [ajay.khatri@igl.co.in](mailto:ajay.khatri@igl.co.in) dated 24.08.2021

The said CNG station building is comprised of single story building.

/	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL/OISD-179	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12 mts N/A N/A	Provided Directly Accessible N/A	MR MR N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mt.	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A N/A	N/A N/A	N/A N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	03 DCP mounted trolley 75 kg each, 10 kg DCP- 10 & CO <sub>2</sub> -3, Water mist Foam trolley- 01 ISI marked	Provided Provided Provided	MR MR MR

6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Gas & Flame detectors, hand held explosive meter	Provided	MR
		Ground Floor	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR


N/S

N/A  
N/A  
N/A  
/R

Provision of Lifts. Provided but not commissioned				
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire Buckets filled with sand, No smoking boards displayed in Hindi & English, electrical wiring in metal conduit, CO <sub>2</sub> flooding system		Provided MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.  
DFA is put up for approval & signature please.



*[Handwritten Signature]* 15/9/21

P.V. Rathee  
Asstt. Div. Officer (SRD)

*[Handwritten Signature]* D.O. (SRD)

*[Handwritten Signature]* 17/09/2021  
By CFO (SRD) *[Handwritten Signature]* 20/9

*[Handwritten Signature]*

*[Handwritten Signature]* 21/9

*[Handwritten Signature]* 20/9/2021

*[Handwritten Signature]* Asstt. SRD