

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F6/DFS/MS/School/MN/2021 785

Dated: 27/9/2021

FIRE SAFETY CERTIFICATE

Certified that the building of M.C. Pry Co – Edu Model School, Located at Ground and 1<sup>st</sup> Floor, Rampura, Delhi - 110035 Owned/Occupied by M.C Pry Co- Edu Model School comprised of Ground + 1 upper Floor was issued FSC vide letter No. F6/DFS/MS/School/2018/1252 dated 29/05/2018. The premises was re-inspected by the officer concerned by this department on 14/09/2021 in the presence of Smt. Suman Gupta (Principal) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education Govt of NCT of Delhi, and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 27.9.21 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 27.9.21 at New Delhi.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer,  
Delhi Fire Service

Copy to:

1. The Principal, M.C. Pry Co – Edu Model School, Located at Ground and 1<sup>st</sup> Floor, Ram Pura, Delhi - 110035
2. Director of Education, Old Sectt. Delhi-110054

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **The Second Floor shall not be used for School activity.**

M-6

**INSPECTION REPORT**

1. Name & address of the building : M.C. Pry Co – Edu Model School, Located at Ground and 1<sup>st</sup> Floor, Ram Pura, Delhi - 110035
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2018/1252 dated 29/5/2018
5. Fire Safety directives letter No : Cr.No.3298-3398 dated 01/03/2011
6. Date of inspection : 14/09/2021
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO/MN)
8. Name and designation of officers from the building side : Suman Gupta (Principal)
9. Year of Construction : 1950(As per previous inspection report dtd 09/05/2018)
10. Applicant's letter No. : Email Dated 28/08/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement(As per. Prev. Insp. Report dtd-09/05/2018	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Gate width</li> </ul>	Required	370cms Provided	MR
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	1.5mts or less & 0.75mts	105cm & 110cm	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5mts	238cm Provided	MR
	g. Door Size	1mtrs	1m Provided (Including door frame)	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	08 nos	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	CO <sub>2</sub> , ABC type	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR

88

N-7

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
		NA	NA	NA
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level		NA	
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

82

15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			NA
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire Control Room			NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/School/2018/1252 dated 29/05/2018 Renewal in accordance with the circular No.F16/Estate/CC/fire safety/2011/3298-3398 dated 01/03/2011 issued by the D.O.E.is recommended.

230/ADO/MN  
17/09/2021

~~ADO (MN)~~

~~ADO (MN)~~  
17/09/2021

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

~~ADO (MN)~~  
17/09/2021

~~ADO (MN)~~  
20/09/2021

ADO (MN) Sir, F-T is put up for your approval. Uj. plz

~~ADO (MN)~~

~~ADO (MN)~~  
29/09/2021

~~ADO (MN)~~  
24/09/2021

MS/ all